

SUPPLIER < -- > FRIENDLY < -- > CUSTOMER

DAIRY BUSINESS MANAGEMENT SYSTEMS

**QUALITY SYSTEM DOCUMENTATION
(ISO – 9001: 2000)**

MODULE-III

ENGINEERING MANUAL

**INNOVATIVE BUSINESS IMPROVEMENTS (P) LTD.
Regd. Office #53-A, Sector 18-A CHANDIGARH-160018
Tel:0172-2724872 Cell: 9815961853 email:ibiu@hotmail.com**

“WHITE REVOLUTION THROUGH QUIET EVOLUTION”

| | |
|--|-------------------|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD. | Page No. 1 |
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | Date : - 01.04.04 |

| SR NO | TABLE OF CONTENTS | PAGE NO FROM - TO |
|--------------|----------------------------|--------------------------|
| 1. | TABLE OF CONTENTS | 01 TO 01 |
| 2. | LIST OF REVISIONS | 02 TO 02 |
| 3. | SCOPE | 03 TO 03 |
| 4. | OBJECTIVES | 04 TO 04 |
| 5. | DEPARTMENTAL STRUCTURE | 05 TO 05 |
| 6. | DUTIES & RESPONSIBILITIES | 06 TO 13 |
| 7. | PROCEDURES | 14 TO 18 |
| 8. | WORKING INSTRUCTIONS | 18 TO 24 |
| 9. | CONTINUAL IMPROVEMENTS | 25 TO 25 |
| 10. | CONTROL OF QUALITY RECORDS | 25 TO 25 |
| 11. | ANNEXURES | 01 TO 20 |
| 12. | ANNEXURE (N) | 01 TO 07 |
| 13. | FORMATS | 01 TO 25 |

| | |
|-------------------------------|-------------------------------|
| Prepared by H O D | Approved by CEO |
| Signature _____ Date 01.04.04 | Signature _____ Date 01.04.04 |
| Issue No. 01 | Revision No. 0 |
| Date 01.04.04 | Date 01.04.04 |

| | |
|--|---|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD. | Page No. 3 |
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | Date : - 01.04.04 |
| <p style="text-align: center;">3. SCOPE</p> <p>The procedures of the Engineering department cover activities pertaining to Preventive, Corrective, Annual Maintenance of plant and machinery. It also includes maintenance, inspection, measuring and test instruments.</p> | |
| Prepared by H O D | Approved by CEO |
| Signature _____ Date 01.04.04 | Signature _____ Date 01.04.04 |
| Issue No. 01 Date 01.04.04 | Revision No. 0 Date 01.04.04 |

[QMMRP - 03]

| | |
|--|-------------------|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD. | Page No. 4 |
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | Date : - 01.04.04 |


4.0 OBJECTIVES

- 4.1 Implementation of Lubrication and Preventive Maintenance Schedules.
- 4.2 To monitor maintenance expenditure of different sections i.e. Dairy Machinery, Utilities & electrical equipment.
- 4.3 To minimize number of Breakdowns & Production Down time.
- 4.4 To improve the performance of machinery for optimizing productivity.
- 4.5 Calibration of Instruments as per specified schedules.
- 4.6 Ensure continuous improvement for optimizing fuel utilization, power consumption and to reduce maintenance expenditure.

| | |
|---|---|
| Prepared by H O D | Approved by CEO |
| Signature _____ Date 01.04.04 | Signature _____ Date 01.04.04 |
| Issue No. 01 Date 01.04.04 | Revision No. 0 Date 01.04.04 |

[QMMRP - 03]

5. DEPARTMENTAL STRUCTURE



Prepared by **H O D**

Approved by **CEO**

Signature _____ Date 01.04.04

Signature _____ Date 01.04.04

Issue No. 01 Date 01.04.04

Revision No. 0 Date 01.04.04

| | |
|--|-------------------|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD. | Page No. 6 |
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | Date : - 01.04.04 |

6.1. DUTIES & RESPONSIBILITIES OF H.O.D. (ENGINEERING)

- 6.1.1 To ensure effective implementation of preventive maintenance schedules of Refrigeration, Boiler Section, Water Supply, Effluent Treatment Plant, Electrical & Dairy equipment.
- 6.1.2 To ensure that logbooks and other preventive maintenance records of Refrigeration, Boiler, Water Supply, Effluent Treatment Plant, Electrical & Mechanical Section are maintained for daily monitoring.
- 6.1.3 To ensure smooth working of boiler and its accessories, Refrigeration Plant, Water Supply, Effluent Treatment and dairy plant / equipment.
- 6.1.4 To ensure break down free performance of critical equipment.
- 6.1.5 To ensure smooth running of Effluent Treatment Plant as per statutory requirements of Punjab Pollution Control Board.
- 6.1.6 To plan and carry out annual maintenance schedule of Boiler, Refrigeration Plant, Water Supply, Effluent Treatment Plant, Dairy & Electrical equipment.
- 6.1.7 To ensure optimum utilization of Water / Steam / Lubricants & other consumables.
- 6.1.8 To coordinate and control the working of Engineering department in all the three shifts and ensure proper discipline among the staff.
- 6.1.9 Liaison with Govt. authorities like Pollution Control Board, Director of boilers & Chief electrical Inspector & also ensure payments of all statutory dues relating to Machinery, Electrical, Boiler, Cold store and Effluent Treatment Plant.
- 6.1.10 To forecast demands, coordinate and arrange for timely purchase of spare parts and maintenance materials so as to ensure smooth working of all the equipment.
- 6.1.11 To ensure maintenance of building pertaining to all civil works.
- 6.1.12 To arrange the installation of new equipment and modifications of dairy equipment in the plant / milk chilling centres.
- 6.1.13 Ensure timely renewal of licenses / certificates and annual maintenance contract.
- 6.1.14 Ensure that all pouch machines, weighbridge, bottle filler and dead weights are calibrated from Weights and Measurements department on due dates.

| | |
|---|---|
| Prepared by H O D | Approved by CEO |
| Signature _____ Date 01.04.04 | Signature _____ Date 01.04.04 |
| Issue No. 01 Date 01.04.04 | Revision No. 0 Date 01.04.04 |

[QMMRP - 03]

| | | | |
|--|--|---|--|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD. | | Page No. 7 | |
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | | Date : - 01.04.04 | |
| <p>6.1.15 Ensure that all pressure vessels and lifting equipment are tested as per factory acts on due date.</p> <p>6.1.16 Any other duty assigned by the management from time to time.</p> <p>6.2 DUTIES AND RESPONSIBILITIES OF FOREMAN (MECHANICAL)</p> <p>6.2.1. To carry out lubrication and preventive maintenance jobs with the help of shift technicians/ Helpers/ Trainees as per specified schedules.</p> <p>6.2.2. To ensure that all Dairy Equipment and ancillary equipment are in working order all the time.</p> <p>6.2.3. To ensure smooth operation, checking of all critical equipment with special attention.</p> <p>6.2.4. To ensure maximum possible reduction in number of break downs and production downtime.</p> <p>6.2.5. To maintain all prescribed sectional records.</p> <p>6.2.6. To carry out installation of new equipment and modifications to existing equipment and pipelines as per directions of departmental head.</p> <p>6.2.7. To ensure timely repair of leakages in utilities pipelines.</p> <p>6.2.8. To maintain cleanliness in workshop.</p> <p>6.2.9. To ensure the smooth running of Effluent Treatment Plant as per norms.</p> <p>6.2.10. Ensure effective corrective maintenance of all equipment on day to day basis.</p> <p>6.2.11. Ensure that history sheet of each machinery in respect of expenditure is maintained.</p> <p>6.2.12. Ensure that implementation tasks for continuous improvement are carried out.</p> <p>6.2.13. Any other duty assigned by the management from time to time.</p> | | | |
| Prepared by H O D | | Approved by CEO | |
| Signature _____ Date 01.04.04 | | Signature _____ Date 01.04.04 | |
| Issue No. 01 Date 01.04.04 | | Revision No. 0 Date 01.04.04 | |

[QMMRP - 03]

6.3. DUTIES AND RESPONSIBILITIES OF FOREMAN (ELECTRICAL)

- 6.3.1. To carry out lubrication and preventive, corrective, annual maintenance jobs with the help of shift technician / helper / trainee as per the prescribed frequencies.
- 6.3.2. To inspect all electrical equipment / motors daily for any abnormality.
- 6.3.3. To check the working accuracy of all electrical testing/measuring instruments including Voltmeters, Ampere meters at regular intervals.
- 6.3.4. To minimize breakdowns and production downtime.
- 6.3.5. To take all possible steps for minimizing electrical losses.
- 6.3.6. To maintain all the records of engineering department as prescribed.
- 6.3.7. To ensure that all electrical equipment, controls and lights always remain in working order.
- 6.3.8. To carry out installation of new equipment and modification of other equipment as per directions of departmental head.
- 6.3.9. To maintain cleanliness in electrical section at all times
- 6.3.10. To ensure proper earthing of equipment and protection as per statutory requirements.
- 6.3.11. To achieve specified power factor as per statutory requirements of Punjab State Electrical Board (PSEB).
- 6.3.12. To ensure calibration of all the instruments of factory as per specified schedules.
- 6.3.13. To ensure that implementation tasks are carried out for continuous improvement.
- 6.3.14. To ensure that all preventive steps are taken to avoid electrical motors getting burnt.
- 6.3.15. Any other duty assigned by the management from time to time.

Prepared by **H O D**

Approved by **CEO**

Signature _____ Date 01.04.04

Signature _____ Date 01.04.04

Issue No. 01 Date 01.04.04

Revision No. 0 Date 01.04.04

| | |
|--|-------------------|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD. | Page No. 9 |
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | Date : - 01.04.04 |

6.4 DUTIES AND RESPONSIBILITIES OF JUNIOR FOREMAN (REFRIGERATION)

- 6.4.1. To carry out lubrication and preventive, corrective, annual maintenance jobs effectively with the help of shift technicians as per the specified schedules.
- 6.4.2. To check all critical equipment daily with special attention for any abnormality.
- 6.4.3. To check and plug ammonia & air leakage if any as per specified schedules.
- 6.4.4. To ensure periodic cleaning of atmospheric condenser and its tank.
- 6.4.5. To maintain log books and relevant records of the section
- 6.4.6. To monitor performance of ammonia/air compressors, supply pumps and tubewell on daily basis to ensure maximum possible energy savings.
- 6.4.7. To check and ensure minimum wastages of chilled water, well water and compressed air.
- 6.4.8. To carry out installation of new equipment and modification of existing equipment and pipelines as per requirement.
- 6.4.9. To keep refrigeration section neat & clean at all the times.
- 6.4.10. To maintain the refrigeration equipment used for ice cream manufacturing section.
- 6.4.11. Any other duty assigned by the management from time to time.

| | |
|---|---|
| Prepared by H O D | Approved by CEO |
| Signature _____ Date 01.04.04 | Signature _____ Date 01.04.04 |
| Issue No. 01 Date 01.04.04 | Revision No. 0 Date 01.04.04 |

[QMMRP - 03]

| | |
|--|-------------------|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD. | Page No. 10 |
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | Date : - 01.04.04 |

6.5. DUTIES AND RESPONSIBILITIES OF FOREMAN (BOILER)

- 6.5.1. To carry out lubrication and preventive, corrective, annual maintenance jobs effectively with the help of shift attendants and foreman (Mech.) as per the prescribed schedules.
- 6.5.2. To check all critical equipment/motors daily with special attention for any abnormality.
- 6.5.3. To check and plug the steam leakages of pipelines on daily basis.
- 6.5.4. To plan and supervise husk feeding and ash disposal operations.
- 6.5.5. To plan and execute effective stacking / unloading of husk so that husk be fed with minimum labor and maintain husk yard for minimizing losses.
- 6.5.6. To check proper working of all steam traps on steam headers and feeder lines.
- 6.5.7. To monitor the quality of feed water / boiler water and dosing of the required boiler chemicals regularly.
- 6.5.8. To maintain all prescribed sectional records.
- 6.5.9. To make all necessary arrangements required for inspection by boiler inspector.
- 6.5.10. To carry out installation of new equipment and modifications of other equipment as per requirement.
- 6.5.11. To maintain boiler house neat and clean.
- 6.5.12. Any other duty assigned by the management from time to time.

| | |
|---|---|
| Prepared by H O D | Approved by CEO |
| Signature _____ Date 01.04.04 | Signature _____ Date 01.04.04 |
| Issue No. 01 Date 01.04.04 | Revision No. 0 Date 01.04.04 |

[QMMRP - 03]

| | | | |
|---|--|---|--|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD. | | Page No. 11 | |
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | | Date : - 01.04.04 | |
| <p>6.6. DUTIES & RESPONSIBILITIES OF TECHNICIAN (MECHANICAL)/WELDER CUM FITTER/SHIFT TECHNICIAN FITTER</p> <p>6.6.1. To complete allotted jobs within the specified time frame.</p> <p>6.6.2. To attend to complaints of mechanical faults during the shift within the shortest possible time.</p> <p>6.6.3. To make periodic visits to all sections of the plants for ensuring smooth working of plant and machinery.</p> <p>6.6.4. To carry out preventive and annual maintenance of plant machinery as per specified schedule.</p> <p>6.6.5. To ensure minimum possible production downtime during the shift.</p> <p>6.6.6. To make entries in log books and other records related to the assignment.</p> <p>6.6.7. To operate effluent treatment plant in absence of effluent treatment plant operator as per requirement.</p> <p>6.6.8. Any other duty assigned by the management from time to time.</p> <p>6.7 DUTIES AND RESPONSIBILITIES OF OPERATOR/TECHNICIAN (REFRIGERATION)</p> <p>6.7.1 To operate refrigeration plant as per specified procedure smoothly.</p> <p>6.7.2 To operate air compressors smoothly and as per the requirements of production activities.</p> <p>6.7.3 To maintain cold store temperatures as per the functional requirements.</p> <p>6.7.4 To provide chilled water to different sections of the plant at required temperatures.</p> <p>6.7.5 To monitor the working of all equipment and inform to the foreman if any abnormality is observed.</p> <p>6.7.6 To ensure continuous supply of well water to the plant by operating submersible pump and water supply pumps as per requirement.</p> | | | |
| Prepared by H O D | | Approved by CEO | |
| Signature _____ Date 01.04.04 | | Signature _____ Date 01.04.04 | |
| Issue No. 01 Date 01.04.04 | | Revision No. 0 Date 01.04.04 | |

[QMMRP - 03]

| | |
|--|-------------------|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD. | Page No. 12 |
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | Date : - 01.04.04 |

- 6.7.7 To minimize the wastage of chilled water, well water, ammonia gas & compressed air.
- 6.7.8 To complete other allotted maintenance jobs within the specified time frame.
- 6.7.9 To make entries of observations in the log book.
- 6.7.10 To assist the maintenance staff, in carrying out preventive and corrective maintenance of refrigeration and allied equipment.
- 6.7.11 Any other duty assigned by the management from time to time.

6.8 DUTIES AND RESPONSIBILITIES OF BOILER ATTENDANT (I CLASS & II CLASS)

- 6.8.1 To operate the boiler and the ancillaries smoothly as per specified procedure.
- 6.8.2 To ensure continuous supply of steam at required pressure to all sections of the plant.
- 6.8.3 To supervise husk feeding operation for ensuring continuous feeding of husk to the boiler as per requirement.
- 6.8.4 To drain / clean Boiler beds as and when required.
- 6.8.5 To carry out blow down as per specified instructions.
- 6.8.6 To ensure minimum possible wastage of husk, coal, sand, steam, water and power.
- 6.8.7 To make entry of observations in the log- books.
- 6.8.8 To assist the maintenance staff in carrying out preventive and corrective maintenance of steam raising equipment.
- 6.8.9 To check all the safety mountings and accessories of boiler as per specified schedules.
- 6.8.10 Any other duty assigned by the management from time to time.

| | |
|---|---|
| Prepared by H O D | Approved by CEO |
| Signature _____ Date 01.04.04 | Signature _____ Date 01.04.04 |
| Issue No. 01 Date 01.04.04 | Revision No. 0 Date 01.04.04 |

[QMMRP - 03]

| | | | |
|---|--|-------------------------------|--|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD. | | Page No. 13 | |
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | | Date : - 01.04.04 | |
| <p>6.9 DUTIES AND RESPONSIBILITIES OF TECHNICIAN/SHIFT TECHNICIAN (ELECTRICAL)</p> <p>6.9.1 To complete allotted jobs within the specified time frame.</p> <p>6.9.2 To attend the complaints of electrical faults during the shift within shortest possible time.</p> <p>6.9.3 To carry out periodic maintenance of electrical equipment.</p> <p>6.9.4 To note readings of all the energy meters during 'A' shift and to maintain log book in each shift.</p> <p>6.9.5 Carry out inspection of running motors in each shift.</p> <p>6.9.6 Ensure cleaning of diesel generator sets and all panel boards.</p> <p>6.9.7 Ensure that diesel generator set is started during peak load hours as per requirement of production department.</p> <p>6.9.8 Ensure that all the lights of plant are switched off early in the morning.</p> <p>6.9.9 Any other duty assigned by the management from time to time.</p> <p>6.10 DUTIES RESPONSIBILITIES OF OPERATOR (EFFLUENT TREATMENT PLANT)</p> <p>6.10.1 To operate the effluent treatment plant as per specified procedure.</p> <p>6.10.2 To ensure that all equipment of effluent treatment plant are always in running condition.</p> <p>6.10.3 Carry out maintenance all the equipment of effluent treatment plant during break down with the help of foreman / fitter / electrician.</p> <p>6.10.4 To ensure running of effluent treatment plant as per norms prescribed by Pollution Control Board.</p> <p>6.10.5 To assist the electrician / technician in workshop to carry out day to day maintenance as per requirement.</p> <p>6.10.6 To maintain logbook of effluent treatment plant on shiftwise basis.</p> <p>6.10.7 Ensure consumption of chemicals as per specified norms.</p> <p>6.10.8 Any other duty assigned by the management from time to time.</p> | | | |
| Prepared by H O D | | Approved by CEO | |
| Signature _____ Date 01.04.04 | | Signature _____ Date 01.04.04 | |
| Issue No. 01 Date 01.04.04 | | Revision No. 0 Date 01.04.04 | |

[QMMRP - 03]

| | |
|--|-------------------|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD. | Page No. 14 |
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | Date : - 01.04.04 |

7. PROCEDURES

7.1 For smooth running of plant & machinery, preventive maintenance schedules for all sections of engineering department have been prepared.

7.1.1 The lubrication schedules of dairy machinery have been prepared which is given at annexure " A ".

7.1.2 Preventive & maintenance schedules for dairy machinery have been prepared which are given at annexure "B". Work is carried out as per schedules by the fitter / operator / mechanic and duly checked and signed by foreman and recorded in the register "Performance history of the dairy equipment" (QME-06).

7.1.3 Preventive maintenance schedules for electrical equipment have been prepared which are given at annexure " C ". Foreman electrical ensures that these schedules are strictly followed and recorded in the register "Performance history of the electrical equipment." (QME-07).

7.1.4 The preventive maintenance schedules for boiler section have been prepared which are given at annexure " D ". Foreman boiler carries out the preventive maintenance with the help of operator / fireman / technician as per specified frequencies and records in performance history of the boiler equipment register (QME-08). Boiler operations are carried out and maintained by the operator in different shifts. Operator ensures the smooth running of boiler as per specified work instructions mentioned at 8.10.

7.1.5 The preventive maintenance schedules for refrigeration plant have been prepared which are given at annexure "E". Foreman refrigeration ensures that preventive maintenance is carried out as per specified schedule with the help of operator / technician and same is recorded in QME-09. Operators ensure the smooth running of refrigeration plant and air compressors as per specified work instructions mentioned at 8.14 and 8.15.

7.1.6 The preventive maintenance and calibration schedule for the test, measuring, control & weighing instruments have been prepared which is given at annexure " F ". HOD engineering ensures that these schedules are strictly followed and recorded in "Preventive maintenance and calibration schedule" register QME-13 and QME-14.

7.1.7 To ensure smooth running of equipment, a list of recommended lubricants & the purpose for which these are to be used are given at the annexure " H ".

| | |
|---|---|
| Prepared by H O D | Approved by CEO |
| Signature _____ Date 01.04.04 | Signature _____ Date 01.04.04 |
| Issue No. 01 Date 01.04.04 | Revision No. 0 Date 01.04.04 |

[QMMRP - 03]

| | | | |
|--|---|---|--|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD. | | Page No. 15 | |
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | | Date : - 01.04.04 | |
| 7.1.8 | The preventive maintenance schedules for smooth running of diesel generator set have been prepared and given at annexure " J " and strictly followed. These schedules are implemented and recorded by the Foreman (Electrical) in QME-10. | | |
| 7.1.9 | The civil maintenance of all plant building is carried out as per the requirements and is recorded in QME-20. | | |
| 7.1.10 | Separate logbooks for boiler, diesel generating sets, electrical, effluent treatment plant and refrigeration sections are maintained in the respective sections (QME-01 to QME-05). | | |
| 7.1.11 | Log Books of refrigeration plant (QME-01 A) & (QME-01) , Electrical (QME-02 – 05), Diesel Generating sets (QME-03) (A and B), Boiler (QME-04) and Effluent Treatment Plant (QME-05) are maintained in the respective sections. | | |
| 7.1.12 | The lubrication and preventive maintenance schedules have been prepared for the maintenance of plant and machinery. These schedules are being followed as per the details specified in the formats and frequencies detailed therein. | | |
| 7.1.13 | These details are noted down from the format on separate register, maintained in the different sections such as refrigeration. boiler, effluent treatment plant, electrical & mechanical for the month and action taken by the respective operator / mechanics duly verified, checked and signed by the foreman and HOD. These logbooks are the records maintained by the shift operators / foremen in their respective sections. Work is carried out as per schedules by the fitters / operators / mechanics and duly checked and signed by foreman and recorded in the performance history of the equipment of respective sections. | | |
| 7.1.14 | The maintenance of the equipment installed at Milk Chilling Centres is also carried out as 'Milk Chilling Centre Maintenance Report (General) and maintenance report (Electrical) as per annexure " K & L " respectively and preserved in QME-11 & QME-12 respectively. | | |
| 7.1.15 | To maintain basic data of the each equipment,'Basic Equipment Data Sheet' has been prepared in 'Basic Equipment Data Sheet. (QME-15). | | |
| Prepared by H O D | | Approved by CEO | |
| Signature _____ Date 01.04.04 | | Signature _____ Date 01.04.04 | |
| Issue No. 01 Date 01.04.04 | | Revision No. 0 Date 01.04.04 | |

[QMMRP - 03]

| | |
|--|-------------------|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD. | Page No. 16 |
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | Date : - 01.04.04 |

7.1.16 However, annual maintenance schedules are prepared in the month of April and carried out in the month of May, June and July every year. The annual maintenance is also carried out especially for the equipment, which were giving problems frequently as observed from the performance history of the equipment register. The annual maintenance schedule is specified at annexure " M " and recorded in annual maintenance schedules format (QME-16)

7.1.17 For routine corrective maintenance, a printed formats in duplicate namely 'Corrective Maintenance Record' (QME-17) is maintained.

Whenever any break down/defect takes place during the shift, it is recorded by the production shift incharge in QME-17 and a copy of that is handed over to respective shift technicians to attend the same. Reasons for the breakdown are also investigated and remedial measures are taken. This format is duly filled/ signed by the technician of respective section who attends the break down and is duly checked, verified and recorded in performance history of the equipment by respective Foreman.

7.1.18 Daily report of engineering department (QME-18) is prepared to monitor the breakdowns in the different sections, fuel, electricity, diesel, water consumption, unit generated by diesel generator set, running hours of refrigeration compressors etc. The consumption of utilities are computed and compared with the specified norms. If any deviation is observed, corrective measures are initiated by concerned officer to achieve the specified targets.

| | |
|---|---|
| Prepared by H O D | Approved by CEO |
| Signature _____ Date 01.04.04 | Signature _____ Date 01.04.04 |
| Issue No. 01 Date 01.04.04 | Revision No. 0 Date 01.04.04 |

[QMMRP - 03]

| | | |
|--|--|-------------------------------|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD. | | Page No. 17 |
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | | Date : - 01.04.04 |
| 7.2 | Inspection of Measuring, Control & Test Equipment. | |
| 7.2.1 | Calibration / Check of standard instrument. | |
| | Test equipment used is mentioned below: - | |
| | 1) Zeal Thermometer: - It is used for calibration of all dial type temps. Gauges. | |
| | Location :- | IBI/ENGG/ALM-01/SL-03 |
| | 2) R.T.D.Calibrator: - It is used for calibration of Digital temp. Indicators. | |
| | Location :- | IBI/ENGG/ALM-01/SL-03 |
| | 3) Pressure Gauge: - It is used to check & calibrate pressure measuring & control Comparator instruments. | |
| | Location: - | Work Shop |
| | 4) Manometer: - The manometer is used for calibration of draught and the Vacuum gauges of the Powder plant. | |
| | Location :- | Work Shop |
| | 5) Clampmeter :- To check the voltage / amperes. | |
| | 6) Digital Multimeter :- The multimeter is used for checking of voltage / amperes and electronic components. | |
| | Location :- | IBI/ENGG/ALM-01/SL-03 |
| 7.2.2 | The standard instruments of engineering section are calibrated from approved authorised laboratory annually to ensure that instruments are perfect and certificate are obtain for each instrument and preserved in QME-19. The frequency of recheck/calibration of the inspection/-testing instrument is fixed once in a year for all the instruments. | |
| Prepared by H O D | | Approved by CEO |
| Signature _____ Date 01.04.04 | | Signature _____ Date 01.04.04 |
| Issue No. 01 | Date 01.04.04 | Revision No. 0 Date 01.04.04 |

[QMMRP - 03]

7.2.3 CALIBRATION METHOD

All the measuring & control instruments are calibrated as per the fixed frequency schedule. The calibration procedures is mentioned in the work instructions at 8.0.0

Even if a minor deviation is found in the calibrated instrument, the effect of this on finished product is ascertained as per the parameters of final quality checks / inspection by the quality assurance department.

8. WORK INSTRUCTIONS

8.1 Calibration of Digital Temperature Indicator:

8.1.1 There are two pots inside the temperature indicator. The display side first pot is (103) for zero setting and second trimpot (102) for gain calibration.

8.1.2 Feed 100:00 ohms to the inputs terminal A,B,B' from a decade resistance box using first trimpot adjust 0.00.

8.1.3 Feed 138.50 ohms and adjust the second trimpot so that it indicates 100 degree C.

8.1.4 Repeat steps 8.1.2 and 8.1.3 till no further adjustment is required.

8.2 Calibration of Infra Balance for Moisture Testing

8.2.1 To calibrate the infra red balance initially, adjust the scale at 100 % on fix point (i.e. reference point with right hand side knob.

8.2.2 Adjust the pointer at reference point with left hand side knob

8.2.3 After setting of pointer, reference point and scale, place 5 gm standard weight on pan and rotate the scale upto zero percent with right hand side knob. If the pointer, reference point & zero percent scale concide, the balance is calibrated.

8.2.4 If all three (pointer, reference point & zero percent) not concide, take off the weight from pan then adjust the tension of torsion wire, also adjust length of arm as per requirement.

8.2.5 After adjustment follow 8.2.1 to 8.2.3 steps till final calibration is achieved.

| | |
|---|---|
| Prepared by H O D | Approved by CEO |
| Signature _____ Date 01.04.04 | Signature _____ Date 01.04.04 |
| Issue No. 01 Date 01.04.04 | Revision No. 0 Date 01.04.04 |

| | | | |
|--|--|---|--|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD. | | Page No. 19 | |
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | | Date : - 01.04.04 | |
| <p>8.3 Calibration of West & Chino Controller</p> <p>8.3.1 The West & Chino make temperature controller are for steam pressure & temperature controls respectively. These are fitted in powder plant control panel. The control's softwares are calibrated as per the operation manual.</p> <p>8.4 Checking of Volt Meter.</p> <p>8.4.1 There is a screw in right bottom side of front glass of voltmeter for zero adjustment.</p> <p>8.4.2 Put the phase selector switch at off position.</p> <p>8.4.3 Now meter will show zero volts. If there is some deviation then adjust zero by zero adjustment mention in 8.4.1.</p> <p>8.4.4 Put the selector switch on and cross check the voltage with multimeter, if found variation put a tag of corrective factor accordingly on meter.</p> <p>8.5 Checking of Ampere Meters</p> <p>8.5.1 Follow 8.4.1, 8.4.2 and 8.4.3.</p> <p>8.5.2 Put the system on load and cross check the current by tong tester if variation is found then paste a corrective factor on meter or replace the meter.</p> <p>8.6 Calibration of Temperature Gauges</p> <p>8.6.1 Take three readings of temperature according to the range of gauge i.e. for 0-100° centigrade gauge; take reading at 0, 50 & 100 ° centigrade.</p> <p>8.6.2 Check the exact temperature of media with testing instrument.</p> <p>8.6.3 Dip the gauge sensor in a media maintained at 0° C and adjust 0°C with pointer adjustment on gauge.</p> <p>8.6.4 Now dip the gauge sensor in media maintained at 100°C centigrade if variation observed adjust the range with angular adjustment (adjustment on sector).</p> <p>8.6.5 Repeat 8.6.3 and 8.6.4 till nil variation on gauge is achieved.</p> <p>8.6.6 Follow same procedure for different ranges of gauges with different media.</p> | | | |
| Prepared by H O D | | Approved by CEO | |
| Signature _____ Date 01.04.04 | | Signature _____ Date 01.04.04 | |
| Issue No. 01 Date 01.04.04 | | Revision No. 0 Date 01.04.04 | |

[QMMRP - 03]

| | |
|--|-------------------|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD. | Page No. 20 |
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | Date : - 01.04.04 |

8.7 Calibration of Pressure Gauges

- 8.7.1 Fix the gauge on pressure gauge comparator.
- 8.7.2 Adjust zero on dial with pointer adjustment.
- 8.7.3 Apply pressure with pump upto the gauge range.
- 8.7.4 If there is variation, adjust the range with angular adjustment (adjustment on sector).
- 8.7.5 Repeat 8.7.2 to 8.7.4 till gauge shows accurate reading,

8.8 Calibration of Drought Gauges

- 8.8.1 Check the zero level on U tube manometer.
- 8.8.2 Tee off the gauge on one side of manometer.
- 8.8.3 Adjust zero with zero setting mentioned on backside of gauge.
- 8.8.4 Apply air pressure to the common airline of manometer and gauge, up to the gauge range. If found variation, adjust the range with span adjustment mentioned backside of gauge.
- 8.8.5 Repeat 8.8.3 and 8.8.4 till gauge shows accurate reading.

8.9 Calibration procedure of Weighing Scales: -

8.9.1 Calibration procedure for eagle/indosaw makes weighing scales.

- 8.9.1.1 Switch on the scale, check the zero on display.
- 8.9.1.2 If scales shows zero then put the standard weight on the platform of the weighing scale. (The standard weight should be minimum half of the capacity of the scale) If scale reading varies from actual weight than adjust the reading with span potentiometer.
- 8.9.1.3 Repeat the procedure 8.9.1.1 and 8.9.1.2 till scale shows accurate reading.

| | |
|---|---|
| Prepared by H O D | Approved by CEO |
| Signature _____ Date 01.04.04 | Signature _____ Date 01.04.04 |
| Issue No. 01 Date 01.04.04 | Revision No. 0 Date 01.04.04 |

[QMMRP - 03]

| | | | |
|---|--|---|--|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD. | | Page No. 21 | |
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | | Date : - 01.04.04 | |
| <p>8.9.2 Calibration procedure for Samson makes weighing scale</p> <p>8.9.2.1 Switch on the scale and press the mode button continuously during the count down. After count down, the scale will show 'Cal' and Y/N alternatively. Press mode button again, the scale will show 5 kg or 10 kg alternatively on display.</p> <p>8.9.2.2 Put 5 kg or 10 kg calibrated weight on the platform of the scale. 'Cal done' will appear on the panel with sound of three beeps and display will show the weight.</p> <p>8.10 WORK INSTRUCTIONS OF BOILER</p> <p>8.10.1 Switch on the panel with main switch.</p> <p>8.10.2 Open the isolation valves of feed water pump.</p> <p>8.10.3 Start the feed water pump and maintain the water level in boiler drum up to the 3 / 4 of gauge glass.</p> <p>8.10.4 Make the six inch thick silica sand bed in boiler furnace.</p> <p>8.10.5 Open the induced draft and forced draft fan damper of respective bed that you are going to start.</p> <p>8.10.6 Start the induced draft fan.</p> <p>8.10.7 Adjust the induced draft fan & forced draft fan damper of respective bed for proper combustion.</p> <p>8.10.8 Put the fire in boiler bed with help of charcoal and kerosene.</p> <p>8.10.9 Raise the temperature of bed with the help of charcoal and by varying the force draft fan damper slowly.</p> <p>8.10.10 Increase the bed temperature upto 400 ° C.</p> <p>8.10.11 Start the husk feeder of respective bed and increase the husk feeding gradually by speed regulation knob of rpm controller of respective husk feeder.</p> <p>8.10.12 Check the smoke at chimney out let and adjust the dampers, husk feed as per requirement of load and in such a manner that flue gases at chimney out let must transmit light brownish in color.</p> <p>8.10.13 Carry out blow down to maintain TDS at 3500 max.</p> | | | |
| Prepared by H O D | | Approved by CEO | |
| Signature _____ Date 01.04.04 | | Signature _____ Date 01.04.04 | |
| Issue No. 01 Date 01.04.04 | | Revision No. 0 Date 01.04.04 | |

[QMMRP - 03]

| | |
|--|-------------------|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD. | Page No. 22 |
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | Date : - 01.04.04 |

- 8.10.14 Blow off the soot every four hours.
- 8.10.15 Maintain the feed water hardness below 5 PPM by the testing of soft water, condensate from powder plant and feed tank from main lab.

8.11 WORKING INSTRUCTIONS FOR DIESEL GENERATOR SET

- 8.11.1 Inspect the diesel generator sets for engine lube / fuel oil/ water leakage.
- 8.11.2 Check the lube oil level / water level & fuel level in tank with the dipstick and make-up the levels if required.
- 8.11.3 Check the battery terminal / acid level of storage battery and make up the level if required.
- 8.11.4 Keep the engine speed governor lever at low speed.
- 8.11.5 Turn on the start switch installed at engine monitor panel.
- 8.11.6 Set the engine speed at 1500 RPM by governor lever.
- 8.11.7 Check the oil pressure (60 psi minimum), fuel pressure (25 psi minimum), alternator current and engine cooling water temperature (pointer should be at green area of temperature gauge) on engine monitor panel on hourly basis.
- 8.11.8 Check the voltage at the respective diesel generator panel voltmeter. The voltage should be 400.(+ / - 10 volt)

8.12 WORK INSTRUCTIONS FOR DIESEL GENERATOR CHANGE OVER WHEN LOAD IS LESS THAN 550 AMPERE (when powder plant is not running)

- 8.12.1 Switch off the main air circuit breaker on main distribution panel by pressing red button
- 8.12.2 Switch off the capacitor panel.
- 8.12.3 Follow work instructions for diesel generator set from no 8.11.1 to 8.11.8
- 8.12.4 Switch on the air circuit breaker at respective diesel generator monitor panel.
- 8.12.5 Switch on the air circuit breaker of respective diesel generator set at main low-tension distribution panel.

| | |
|---|---|
| Prepared by H O D | Approved by CEO |
| Signature _____ Date 01.04.04 | Signature _____ Date 01.04.04 |
| Issue No. 01 Date 01.04.04 | Revision No. 0 Date 01.04.04 |

[QMMRP - 03]

| | |
|---|-------------------------------|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD. | Page No. 23 |
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | Date : - 01.04.04 |
| <p>8.13 WORK INSTRUCTION FOR DIESEL GENERATOR CHANGE OVER (When powder plant is running)</p> <p>8.13.1 Follow work instruction from 8.12.1 & 8.12.2.</p> <p>8.13.2 Switch off the bus-coupler - II at main distribution panel.</p> <p>8.13.3 Start both diesel generator set one by one, follow the work instructions 8.11 for each.</p> <p>8.13.4 Follow from 8.12.1 & 8.12.2</p> <p>8.13.5 Switch on the respective diesel generator incommer at main distribution panel.</p> <p>8.14 WORKING INSTRUCTIONS OF AMMONIA COMPRESSOR</p> <p>8.14.1 Check the oil level through gauge glass and make up the level if required.</p> <p>8.14.2 Open the isolation valve of cooling water line to compressor head.</p> <p>8.14.3 Open the isolation valve of cooling water line to oil seal.</p> <p>8.14.4 Open the stop valve of compressor discharge line.</p> <p>8.14.5 Open the suction valve & discharge valve of condenser water pump.</p> <p>8.14.6 Start the compressor motor and observe the amperes drawn by motor. The motor current should be 70 amperes maximum.</p> <p>8.14.7 Open the compressor suction line stop valve slowly.</p> <p>8.14.8 Check the suction pressure(30 psi minimum), oil pressure (20 psi minimum) and discharge pressure(175 psi maximum) of compressor at monitor panel.</p> <p>8.14.9 Check the motor current, it should not be more than 145 amperes.</p> | |
| Prepared by H O D | Approved by CEO |
| Signature _____ Date 01.04.04 | Signature _____ Date 01.04.04 |
| Issue No. 01 Date 01.04.04 | Revision No. 0 Date 01.04.04 |

[QMMRP - 03]

| | |
|--|-------------------|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD. | Page No. 24 |
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | Date : - 01.04.04 |

8.15 WORKING INSTRUCTIONS OF AIR COMPRESSOR

- 8.15.1 Check the oil level through gauge glass.
- 8.15.2 Open the isolation valve of cooling water line to compressor head.
- 8.15.3 Open the suction and discharge valve of condenser water pump.
- 8.15.4 Start the condenser water pump.
- 8.15.5 Open the stop valve of auto loading & unloading auxiliary valve airline.
- 8.15.6 Unload the compressor through loading and unloading valve.
- 8.15.7 Start the compressor motor and monitor the motor current on ampere meter. Motor current must not exceed 45 amperes.
- 8.15.8 Check the oil pressure of compressor on dial gauge.
- 8.15.9 Put the compressor on load with auxiliary valve.

9 CONTINUAL IMPROVEMENT

| | |
|---|---|
| Prepared by H O D | Approved by CEO |
| Signature _____ Date 01.04.04 | Signature _____ Date 01.04.04 |
| Issue No. 01 Date 01.04.04 | Revision No. 0 Date 01.04.04 |

[QMMRP - 03]

| | | | |
|--|--|-------------------------------|--|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD. | | Page No. 25 | |
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | | Date : - 01.04.04 | |
| 9.1 | The prime performance parameters of engineering department have been identified which are given at annexure " N ". | | |
| 9.2 | The performance of each parameter is evaluated by the management-comparing target versus achievement on monthly basis. In case, the performance is below the specified norms, then matter is investigated and corrective & preventive actions are taken to improve the performance. | | |
| 9.3 | The implementation tasks for each prime performance parameters have been prepared which are given at annexure " O ". These implementation tasks are implemented to optimise the performance of individual activities. | | |
| 10 | TRAINING PROGRAMME | | |
| 10.1 | Training needs of individual staff members are identified & training on shop floor is imparted to concerned staff by HOD (Engg) & foreman to improve their skill & knowledge which helps in over all efficiency of prime performance parameters. Personnel department also arranges training programme for staff members from time to time. Please refer to personnel department manual for details. | | |
| 11 | RENEWAL OF LICENCES | | |
| 11.1 | HOD (Engg.) ensures that all licenses are renewed on due dates. The details are given at annexure " P ". | | |
| 13 | ANNUAL MAINTENANCE CONTRACT | | |
| 13.1 | Maintenance contract for rewinding of motors, calibration of electronic weigh scale, / weighbridge and EPBAX are awarded on annual basis. The list is given at annexure " Q ". One month prior to expiry of contract, inquiry letters are sent to different parties inviting sealed quotations, committee members comprising of GM (Works), HOD(Engg.), HOD (Pur) & Mgr (Fin.) open the sealed quotations. Purchase department prepares the comparative statement. Committee members give recommendations to the CEO for awarding the contract to the deserving party. | | |
| 14. | CONTROL OF QUALITY RECORDS | | |
| 14.1 | Quality records in deptt. are kept as per common procedure issued by MR office. | | |
| 14.2 | List of Quality records is attached. | | |
| Prepared by H O D | | Approved by CEO | |
| Signature _____ Date 01.04.04 | | Signature _____ Date 01.04.04 | |
| Issue No. 01 | | Revision No. 0 | |
| Date 01.04.04 | | Date 01.04.04 | |

[QMMRP - 03]

INNOVATIVE BUSINESS IMPROVEMENTS (PVT.)LTD.
LUBRICATION SCHEDULE FOR DAIRY MACHINERY

Annexure - 'A'

| SR NO. | JOB DISCRPTION | LUBRICANT | FREQUENCY QUARTERLY | JOB CODE | GROUP CODE |
|----------------------------------|---|-------------|---------------------|-------------|------------|
| 1 | Greasing of belt conveyer support | Grease AP3 | Quarterly | CB-1 | Q1 |
| 2 | Greasing of can scrubber shaft,nipples,chain etc. | - do - | Monthly | SR-1 | M1 |
| 3 | Check & replace if required Gear box oil of can scrubber | SARVO 220 | - DO - | SR - 2 | M2 |
| 4 | Oil level of homonizer | Servo 150 | - DO - | HM - 1 | M3 |
| 5 | Check quality & level of oil of cream separators worm gear chamber change if required | SERVO 220 | - DO - | CS1CS2+3 | M4 |
| 6 | Greasing of bowl spindle tapered end of cream separators | Grease AP3 | - DO - | CS4-5-6 | M5 |
| 7 | Greasing of crate conveyer rollers | - DO - | Quarterly | PF1 | Q2 |
| 8 | Greasing of Butter churn brake and gear lever. | Grease AP3 | | | |
| 9 | Check the conditions & level of gear oil of butter churn, change if required | SERVO - 220 | Monthly | BC3BC4 | M6 |
| 10 | Greasing of Butter chranner sporting | Grease AP3 | - DO - | BC 5, BC6 | M7 |
| 11 | Check quality & level of oil of Ghee clarifier chamber. Change if required | SERVO-220 | - DO - | GC1 | M8 |
| 12 | Greasing of Ghee/powder tin sealing machine | Grease AP3 | Quarterly | TN1, TN2 | Q3 |
| 13 | Check Quality & level of Air compressor oil of E.T.P., Change if required | SERVO-150 | Monthly | ETP-1 | M9 |
| 14 | Greasing of cap sealing M/c & lid embossing M/c | Grease AP3 | Monthly | GP -1 | M10 |
| 15 | Greasing of vaccum pump & driers | - DO - | - DO - | VP 1,VP2 | M11 |
| 16 | Greasing of Rotary feed pump of dryer powder blender | - DO - | - DO - | RPI,PB1 PB2 | M12 |
| 17 | Greasing of Exhaust, supply, P.C., neck cooling fans | - DO - | - DO - | FAN -14 | M13 |
| 18 | Greasing of feed pump of drier. | - DO - | - DO - | PL | M14 |
| 19 | Greasing of Pulveriser | - DO - | - DO - | PL | M14 |
| LUBRICATION OF GEAR BOXES | | | | | |
| 20 | Car washer | SERVO - 220 | Quarterly | CW | Q18 |
| 21 | Raw Milk Silo agitators | SERVO - 220 | Quarterly | MSA1 - 2 | Q4 |
| 22 | Pasteurised Milk silo agitators | - DO - | - DO - | PMA1- 4 | Q5 |
| 23 | Cream Tank Agitators | - DO - | - DO - | CTA1- 4 | Q6 |
| 24 | Liquid milk tank Agitators | - DO - | - DO - | LMT1 - 2 | Q7 |
| 25 | Reconstitution tank agitators | - DO - | - DO - | RCTA- 1 | Q8 |
| 26 | Butter Melting vat Agitators | - DO - | - DO - | BMA1-2 | Q9 |
| 27 | Ghee Boiler agitators | - DO - | - DO - | GBA1-2 | Q10 |
| 28 | Ghee storage tank agitators | - DO - | - DO - | GSTAI-3 | Q11 |
| 29 | 60 KL milk silo agitators | - DO - | - DO - | MSA3-5 | Q12 |
| 30 | Conc. Vat Agitators | - DO - | - DO - | CTA1-2 | Q13 |
| 31 | Main Dryer chamber rotary valve | - DO - | - DO - | RV-1 | Q14 |
| 32 | Main cyclones Rotary valve | - DO - | - DO - | RV2-2 | Q15 |
| 33 | Bagging cyclone Rotary valve | - DO - | - DO - | RV-4 | Q16 |
| 34 | Chemical dosing pump of E.T.P. | - DO - | - DO - | ETP-2 | Q17 |

| | |
|---------------------------------|-----------------------------------|
| Prepared By H O D | Approved by CEO |
| Signature _____ Date 01.04.04 | Signature _____ Date 01.04.04 |
| Issue No. 01 Date 01.04.04 | Revision No. 0 Date 01.04.04 |

[QMMP - 03]

| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. | | | PAGE NO. 2 | | |
|---|---|-----------------|-----------------|------------|--------------------------------|
| TITLE:- DEPARTMENTAL PROCEDURES ENGINEERING | | | DATE : 01.04.04 | | |
| PREVENTIVE MAINTENANCE SCHEDULE FOR DAIRY MACHINERY | | | | 01 OF 02 | |
| ANNEXURE - 'B' | | | | | |
| S.NO. | PARTICULARS | FREQUENCY | JOB CODE | GROUP CODE | MONTH |
| INDIGENOUS SECTION | | | | | |
| 1 | Homonizer | Quarterly | IS 1 | Q 1 | |
| 2 | Bottle washer | Quarterly | IS 2 | Q 28 | |
| 3 | Pulverizer hammer checking | Quarterly | IS 3 | Q 29 | |
| 4 | Bottle Filler gasket checking and cleaning etc. | Weekly | IS4, IS5 | W 3 | |
| 5 | Belt conveyer checking of rollers bearings belt gearbox | Monthly | IS6 | M 25 | |
| 6 | Khoya kettle steam leakage checking | Monthly | IS7 | M 26 | |
| 7 | Checking sterilizer gasket, steam leakage etc. | Weekly | IS8, IS9, | W 4 | |
| STEAMING BLOCK | | | | | |
| 8 | Check for proper working of steaming block clean the nozzles if required | Quarterly | SB1 | Q2 | |
| CAN SCRUBBER | | | | | |
| 9 | Check Smooth running of gear box | Monthly | SR1 | M1 | |
| 10 | Check Shaft, bearing, oil seal, chain socket repair if required. | Monthly | SR2 | M2 | |
| 11 | Replace worn out bushes if any | | SR3 | M1 | |
| MILK CHILLER | | | | | |
| 12 | Check the condition of plate gaskets, replace if damaged | - do - | MC1 MC2 | M3 | |
| 13 | Clean the thermometers, replace if required | - do - | MC3 | M3 | |
| MILK CREAM PASTEURIZERS | | | | | |
| 14 | Check the condition of feed pumps, dismantle & service all parts | Quarterly | P1 P2 P3 | Q3 | |
| 15 | Check hot water pump impeller, bushes, gland etc., descale/repair /replace parts if required | Quarterly | P4 P5 P6 | Q4 | |
| 16 | Check the condition of filter gaskets & cover gaskets replace if required | Quarterly | P7 P8 P9 | M4 | |
| 17 | Check plate gaskets & replace if damaged | Monthly | P10P11P12 | M5 | |
| 18 | Check for proper working of steam control valve and hot water battery set up | Monthly | P13P14P15 | M6 | |
| 19 | Check for valve leakage | - do - | P16 | M6 | |
| CREAM SEPARATORS | | | | | |
| 20 | Check worm housing & replace oil if necessary | Weekly | CS1CS2SC3 | W1 | |
| 21 | Dismantling of bowl & thorough cleaning of bowl inside parts, cleaning & lubrication of lock ring | Quarterly | CS4CS5CS6 | Q5Q6Q7 | |
| 22 | Thorough overhaul, cleaning & lubrication | Yearly | CS7CS8CS9 | Y1Y2Y3 | |
| POUCH FILLING MACHINE | | | | | |
| 23 | Check the condition of roller supports of crates conveyer, replace worn out balls if required | Quarterly | PF1 | Q8 | |
| 24 | Carry out monthly maintenance of m/c along with m/c operator | Monthly | PF2PF3PF4 | M7M8M9 | |
| | | | PF5 | M24 | |
| 25 | Crate washer nozzle cleaning, pump checking | Weekly | PF6 | W2 | |
| BUTTER CHURN | | | | | |
| 26 | Check the working of clutch assembly, main bearing brake, foundation bolts etc. | Fortnightly | BC1 BC2 | FN1 | |
| 27 | Check the manhole drain valve gaskets | Monthly | BC3 | M10 | |
| 28 | Check gears, bearings brake liner & seals, repair if required | Half Yearly | BC4BC5 | HY1HY2 | |
| Prepared By H O D | | | Approved by CEO | | |
| Signature _____ | | Date : 01.04.04 | Signature _____ | | Date : 01.04.04 |
| Issue No. 01 | | Date : 01.04.04 | Revision No. 0 | | Revision No. 0 Date : 01.04.04 |

[QMMRP - 03]

| S.NO | PARTICULARS | FREQUENCY | JOB CODE | GROUP CODE | MONTH |
|--|--|-------------|-------------------------------|------------|-------|
| GHEE PROCESS SECTION | | | | | |
| 29 | Check Steam trap & safety valves of ghee boilers. | Monthly | GS1 | M11 | |
| 30 | Check for proper working of hot water pumps of butter melting vats | Monthly | GS2 | M12 | |
| 31 | Check gear housing of ghee clarifier & change/replace oil if necessary | Monthly | GS3 | M13 | |
| 32 | Dismantling of bowl & thorough cleaning of bowl, inside parts, lubrication of ghee clarifier. | Quarterly | GS4 | Q9 | |
| 33 | Thorough overhaul, cleaning & lubrication of ghee cleanifier. | Yearly | GS5 | Y4 | |
| GHEE PACKING SECTION | | | | | |
| 34 | Check for proper alignment of ghee & powder tin seamer drive parts & units. | | | | |
| 35 | Check for proper working of condensate pump & also descale & clean the impellers | | | | |
| POWDER PLANT | | | | | |
| 36 | Check for proper working of vacuum pumps, repair if required | - do - | EV1 EV2 | M16 | |
| 37 | Check for proper working of condensate pumps also descale and clean the impellers | - do - | EV3 EV4 | M17 | |
| 38 | Check for proper working of panel mounted instruments replace/repair if required | - do - | EV5 | M18 | |
| 39 | Check for leakage in feed/product/utility lines rectify leaks if any | - do - | EV6 | M19 | |
| 40 | Check for the conditions of impellers seals etc. of the concentrate pumps, replace damaged parts | - do - | EV7 EV8 | M20 | |
| 41 | Check for the condition of V. belts of exhaust fan, delivery fans, cooling & conveying fan and neck cooling fan, vacuum pumps, replace damaged belts | - do - | SD1 SD2 SD3 SD4 | M21 | |
| 42 | Check for proper working of sifter & blender of powder plant, repair if required | - do - | SD6.PB1, PB2 | M22 | |
| DISMANTLING AND SERVICING OF PRODUCT PUMPS :- | | | | | |
| 43 | Milk Pumps in Reception dock | Quarterly | MP1 M2 | Q10 | |
| 44 | Raw milk pumps of feed line | - do - | M3 M4 | Q11 | |
| 45 | Pasteurizer Milk feed Pumps | - do - | M5M6M7 | Q12 | |
| 46 | Cream Pumps in process hall | - do - | CP1CP2CP3 | Q13 | |
| 47 | C.I.P. Return Pumps of milk tanks | - do - | CIP1CIP2 | Q14 | |
| 48 | C.I.P. Return pumps of cream tanks | - do - | CIP3 | Q15 | |
| 49 | Milk return pumps of liquid milk section | - do - | MP8 | Q16 | |
| 50 | Butter milk transfer pumps | - do - | BM1 | Q17 | |
| 51 | Butter transfer pumps of butter melting vat. | - do - | BP1 | Q18 | |
| 52 | Ghee Pumps | - do - | GP1..GP4 | Q19 | |
| 53 | Milk Feed/Booster pumps of evaporator | - do - | MP9 MP10 | Q20 | |
| 54 | Milk Pumps of 60 KL silos | - do - | MP11 MP12 | Q21 | |
| 55 | Roto Pumps of dryer | - do - | RP1 | Q22 | |
| DISMANTLING & SERVICING OF WATER PUMPS | | | | | |
| 56 | Water supply pumps of U.G. Tanks | Half Yearly | UPG1 UPG2 UPG 3 | HY3 | |
| 57 | Spray pond pumps | Half Yearly | SPP1 SPP2 | HY4 | |
| 58 | Submersible pump | Yearly | SBP1 | Y5 | |
| 59 | E.T.P. Feed pumps | - do - | EP1 EP2 | Y6 | |
| 60 | Chemical dosing pumps | - do - | EP3 | Y7 | |
| 61 | Car washer bearing and crank shaft, pipe nozzle checking | Quarterly | CW | Q 17 | |
| MISCELLANIOUS | | | | | |
| 62 | Check for proper working of ETP agitators | Quarterly | ETP1,2,3 | Q23 | |
| 63 | Cleaning of spray pond nozzles | Quarterly | SP1 | Q24 | |
| Prepared By H O D | | | Approved by CEO | | |
| Signature _____ Date 01.04.04 | | | Signature _____ Date 01.04.04 | | |
| Issue No. 01 Date 01.04.04 | | | Revision No. 0 Date 01.04.04 | | |

| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. | | | PAGE NO. | 4 |
|--|--|---|---------------------------------|----------------------------|
| TITLE:- DEPARTMENTAL PROCEDURES ENGINEERING | | | DATE : | 01.04.04 |
| PREVENTIVE MAINTENANCE SCHEDULE ELECTRICAL EQUIPMENT FOR MOTORS & STARTERS | | | 01 OF 04 Annexure- 'C' | |
| SR NO | JOB DISCRPTION | FREQUENCY | JOB CODE | GROOP CODE |
| 1 | TRANSFORMER :- i) Check the condition of jumpers and oil level ii) check silica jel, change if required iii) Check Oil Insulation | Weekly Monthly Half Yearly | TF2 TF3 | M1 HY1 |
| 2 | H.T. O.C.B. :- i) Check the working of following - ON - Off Indication - Selector Switch - 24 V. Batteries & Battry Charger ii) Check the level & quality of oil iii) Check & reset all faulty relays | Weekly Monthly Monthly | HTB1 HTB2 HTB3 | W3 M2 M3 |
| 3 | L.T. PANELS :- i) Cleaning and removing of dust from main L.T. Panel Capacitor control panel, lighting panel, Boiler & Refrigeration panel ii) Clean the dust from all other Panels iii) Check & replace faulty indicators, checking for loose contacts in control cables of all panels | Fortnightly Fortnightly Monthly | LT1 LT2 LT3 | FN2 FN2 M4 |
| 4 | MISC. EQUIPMENT :- i) Check & reset all servo stabilisers ii) Checking for proper working of all laboratory equipment iii) Checking & replacements of fused bulbs & tubes including street lights iv) Checking of pesto flash (fly killer) | Monthly Monthly Monthly Monthly | ME1 ME2 ME3 ME4 ME5 | M5 M6 M7 M8 M9 |
| 5 | PROCEDURES TO BE FOLLOWED DURING QUARTERLY & YEARLY INSPECTION OF MOTORS & STARTERS 1) Check clean & tight contacts of main switch 2) Check & correct size of fuses 3) Check relay range and adjust according to the rating of Motor 4) Check & tight all contacts terminals of startors 5) Check for proper earthing if loose, tight it 6) Check for abnormal sound of bearing if any 7) Clean & tight terminals of motor & junction box 8) Check whether motor is running abnormally hot or normal condition 9) Measure insulation resistance (during yearly inspection only 10)Over hauling of motors unduing replacement of wornout bearings (During yearly inspection only) 11)Check general condition of motors if found unsatisfactory then motor should be overhauled 12) Check & find other defects if any | | | |
| Prepared by H O D | | | Approved by CEO | |
| Signature _____ Date 01.04.04 | | | Signature _____ Date 01.04.04 | |
| Issue No. 01 Date 01.04.04 | | | Revision No. 0 Date 01.04.04 | |

[QMMRP - 03]

| PREVENTIVE MAINTENANCE SCHEDULE FOR MOTORS & STARTERS | | | | | 04 OF 04 |
|---|--|-------------|------------|------------|----------------|
| | | | | | Annexure - 'C' |
| SR NO | MOTOR DISCRPTION | HORSE POWER | MOTOR CODE | GROUP YEAR | CODE QTY |
| VI | 87) Milk Silo (60Kl) Agitator No. 2 | 2.00 | E22 | Y87 | Q15 |
| | 88) Milk Silo (60Kl) Agitator No.3 | 2.00 | E23 | Y88 | Q15 |
| | 89) Milk Spray Pump | 3.50 | E24 | Y89 | Q15 |
| | 90) CIP return pump | 3.50 | e25 | Y90 | Q15 |
| | 91) Exhaust fan | 215.00 | SD1 | Y91 | Q16 |
| | 92) Delivery Fan | 75.00 | SD2 | Y92 | Q16 |
| | 93) Cooling & conveying fan | 25.00 | SD3 | Y93 | Q16 |
| | 94) Atomizer | 40.00 | SD4 | Y94 | Q16 |
| | 95) Neck Cooling fan | 2.00 | SD5 | Y95 | Q16 |
| | 96) Feed Pump | 7.50 | SD6 | Y96 | Q16 |
| | 97) Rotary Valve No.1 (chamber) | 1.50 | SD7 | Y97 | Q16 |
| | 98) Rotary Valve No.2(cyclone) | 0.50 | SD8 | Y98 | Q17 |
| | 99) Rotary Valve No.3(Cyclone) | 0.50 | SD9 | Y99 | Q17 |
| | 99-A) Rotary Valve No. 4 (Bagging cyclone) | | | | |
| | 100) Concentrate tank agitator No. 1 | 1.00 | SD10 | Y100 | Q18 |
| | 101)Concentrate Tank Agitator No.2 | 1.00 | SD11 | Y101 | Q18 |
| | 102) Vibrating sifter No. 1 | 1.25 | SD12 | Y102 | Q18 |
| 103) Vibrating Sifter No.2 | 1.25 | SD13 | Y103 | Q18 | |
| 104) Fire Extinguishing Pump | 5.00 | SD14 | Y104 | Q18 | |
| 105) High pressure pump | 15.00 | SD15 | Y105 | Q18 | |
| 106) Vacuum Pump for packing | 5.00 | SD16 | Y106 | Q18 | |
| 107) Tin Seamer | 2.00 | SD17 | Y107 | Q18 | |
| VII | REFRIGERATION :- | | | | |
| | 108) Ammonia Comp. Motor No. 1 | 125.00 | R1 | Y108 | Q19 |
| | 109) Ammonia Comp. Motor No. 2 | 125.00 | R2 | Y109 | Q19 |
| | 110) Ammonia Comp. Motor No. 3 | 125.00 | R3 | Y110 | Q19 |
| | 111) Air Comp. Motor No. 1 | 30.00 | R4 | Y111 | Q20 |
| | 112) Air Comp. Motor No. 2 | 30.00 | R5 | Y112 | Q20 |
| | 113) IBT Agitator No.1 | 7.50 | R6 | Y113 | Q20 |
| | 114) IBT Agitator No.2 | 7.50 | R7 | Y114 | Q20 |
| | 115) IBT Agitator No.3 | 7.50 | R8 | Y115 | Q20 |
| | 116) Chilled Water pump No.1 | 10.00 | R9 | Y116 | Q21 |
| | 117) Chilled Water Pump No. 2 | 10.00 | R10 | Y117 | Q21 |
| | 118) Chilled Water Pump No. 3 | 10.00 | R11 | Y118 | Q21 |
| | 119) Chilled Water Pump No. 4 | 10.00 | R12 | Y119 | Q21 |
| | 120) Chilled Water Pump No. 5 | 10.00 | R13 | Y120 | Q21 |
| | 121) Condensor Water Pump No. 1 | 10.00 | R14 | Y121 | Q21 |
| | 122) Condensor Water Pump No. 2 | 10.00 | R15 | Y122 | Q21 |
| | 123) Condensor Water Pump No. 3 | 10.00 | R16 | Y123 | Q21 |
| VIII | BOILER :- | | | | |
| | 124) I.D. Fan | 50.00 | B1 | Y124 | Q22 |
| | 125) F.D.Fan Motor No. 1 | 30.00 | B2 | Y125 | Q22 |
| | 126) F.D. Fan Motor No. 2 | 30.00 | B3 | Y126 | Q22 |
| | 127) Rotary valve for A.P.H. | 1.20 | B4 | Y127 | Q23 |
| | 128) Rotary Valve for MDC | 1.20 | B5 | Y128 | Q23 |
| | 129) Husk Feeder No. 1 | 1.00 | B6 | Y129 | Q23 |
| | 130) Husk Feeder No. 2 | 1.00 | B7 | Y130 | Q23 |
| | 131) Feed Water pump No. 1 | 20.00 | B8 | Y131 | Q23 |
| | 132) Feed Water Pump No. 2 | 20.00 | B9 | Y132 | Q23 |
| | 133) Husk Conveyor | 5.00 | B10 | Y133 | Q23 |
| | 134) Vibrating Screen | 2.00 | B11 | Y134 | Q23 |
| IX | E.T.P. :- | | | | |
| | 135) Equilization Tank Agitator | 10.00 | ETP1 | Y135 | Q24 |
| | 136) Aeration Tank Agitator No. 1 | 20.00 | ETP2 | Y136 | Q24 |
| | 137) Aeration TANK Agitator No. 2 | 20.00 | ETP3 | Y137 | Q24 |
| | 138) Feed Pump No.1 | 3.00 | ETP4 | Y138 | Q25 |
| | 139) Feed Pump No. 2 | 3.00 | Y140 | Y139 | Q25 |
| | 140) Chemical Dozing pump | 1.00 | ETP6 | Y140 | Q25 |
| | 141) Air Compressor | 1.00 | ETP7 | Y141 | Q25 |
| X | MISCELLANEOUS :- | | | | |
| | 142) Submersible Pump | 30.00 | MIS1 | Y142 | Q26 |
| | 143) Water Supply Pump No. 1 | 10.00 | MIS2 | Y143 | Q26 |
| | 144) Water supply Pump No. 2 | 10.00 | MIS3 | Y144 | Q26 |
| | 145) Water supply pump No. 3 | 5.00 | MIS4 | Y146 | Q26 |

| | |
|-------------------------------|-------------------------------|
| Prepared by H O D | Approved by CEO |
| Signature _____ Date 01.04.04 | Signature _____ Date 01.04.04 |
| Issue No. 01 | Revision No. 0 |
| Date 01.04.04 | Date 01.04.04 |

| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. | | PAGE NO. 8 | | |
|--|---|-------------------------------|----------|------------|
| TITLE:- DEPARTMENTAL PROCEDURES ENGINEERING | | DATE :01.04.04 | | |
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LT | | ANNEXURE 'D' | | |
| PREVENTIVE MAINTENANCE SCHEDULE FOR STEAM GENERATION | | | | |
| SR NO | JOB DISCRIPTION | FREQUENCY | JOB CODE | GROUP CODE |
| 1 | Check hardness of feed water and alkalinity of boiler water as and when required | Daily | B1 | D |
| 2 | Blow down boiler water at least once in each Shift | - DO - | B2 | D |
| 3 | Blow down mobrey level switch gauge glass | - DO - | B3 | D |
| 4 | Blow off soot from the water tubes | - DO - | B4 | D |
| 5 | Check and regenerate water softner if required | - DO - | B5 | D |
| 6 | Clean the gauge glass in side & out side | Weekly | B6 | W1 |
| 7 | Check the working of mobrey level Switch to ensure that minimum & maximum level are properly controlled | - DO - | B7 | W2 |
| 8 | Check the working of low water cut off /alarm. | - DO - | B8 | W2 |
| 9 | Check the working of safety valves | - DO - | B9 | W3 |
| 10 | Check & ensure that the feed water injector is workign properly | Monthly | B10 | M1 |
| 11 | Check & tightew all foundation bolts, also check tension aligenment of I.D. &F.D. fans | - DO - | B11 | M2 |
| 12 | Check the steam leakages in all steam lines | - DO - | B12 | M3 |
| 13 | Check feed water storage tank & strainers | - DO - | B13 | M4 |
| 14 | Tight stuffing box of water pump | - DO - | B14 | M5 |
| 15 | Take out soot blower pipes & check the holes for blockage,clean holes & refit in position | - DO - | B15 | M6 |
| 16 | Ease steam safty valve & reset | - DO - | B16 | M7 |
| 17 | Check the condition of air nozzles | - DO - | B17 | M8 |
| 18 | Check & reset the pressure reducing station | - DO - | B18 | M9 |
| 19 | Clean the I.D. & F.D. fans Blades | - DO - | B19 | BM1 |
| 20 | Open the main hole fixed on top of boiler & clean the tubes from out side with help of compressed air. | - DO - | B20 | BM2 |
| 21 | Check the conditon of refractory wall of combustion chamber. | Half Yearly | B21 | HY1 |
| 22 | Check the valves for leakage& lap if necessary | - DO - | B22 | HY2 |
| 23 | Check the quantity of resin inside water softner | - DO - | B23 | HY3 |
| 24 | Lubricate the bearings of Pumps,Fans and husk conveyor rollers | - DO - | B24 | HY4 |
| 25 | Check during overhauling of boiler for 1) Repairing of refractory & insulation 2) Cleaning of boiler tubes 3) Descaling of boiler tubes, drum & header 4) Clean in side of flue gas out let 5) Greasing of motors & bearings | Yearly | B25 | Y1 |
| Prepared By H O D | | Approved by CEO | | |
| Signature _____ Date 01.04.04 | | Signature _____ Date 01.04.04 | | |
| Issue No. 01 Date 01.04.04 | | Revision No. 0 Date 01.04.04 | | |

[QMMRP - 03]

| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. | | | | PAGE NO. 9 |
|---|--|-------------------------------|--------------|------------------|
| TITLE :- DEPARTMENTAL PROCEDURES ENGINEERING | | | | DATE :- 01.04.04 |
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. PREVENTIVE MAINTENANCE SCHEDULE FOR REFRIGRATION PLANT ANNEXURE - 'E' | | | | |
| SR. NO. | JOB DISCRIPTION | FREQUENCY | JOB CODE | GROUP CODE |
| 1 | Drain condensate from air receiver & moisture separator | Daily | AC1 | D1 |
| 2 | Check oil & cylinder lubrication oil level of air compressor, change oil if required | Weekly | AC2 | W1 |
| 3 | Check & adjust Lubricator feed rate if required for both the compressors | Weekly | AC3 | W1 |
| 4 | Check safety valve of air compressor for proper functioning | Weekly | AC4 | W1 |
| 5 | Clean suction filter of both the air compressors | Weekly | AC5 | W1 |
| 6 | Keep oil sample in a clean glass over night to settle down the sediment. Change oil if required for all NH3 compressors. | Weekly | RP1,RP2,RP3 | W2 |
| 7 | Drain oil from all oil separators | Weekly | RP4 | W3 |
| 8 | Check for proper working of cold storage diffusers & also Leakage in ammonia valves & pipe lines | Weekly | RP5 | W4 |
| 9 | Clean oil pump strainer of all ammonia compressors | Monthly | RP6,RP7,RP | M1 |
| 10 | Cleaning of oil filter,suction filter & change if required for all ammonia compressor | Monthly | RP8,RP10,RP | M2 |
| 11 | Check tightening of all ammonia compressor's V belts | Monthly | RP12 | M3 |
| 12 | Cleaning of condensor coils | Bimonthly | RP14 | BM1 |
| 13 | Oil purging of duffusers & evaporator coils | Bimonthly | RP15 | BM2 |
| 14 | Inspection & maintenance of refrigeration controls | Quarterly | RP16 | Q 1 |
| 15 | Cleaning of oil separators | Quarterly | RP17,RP18 | Q 2 |
| 16 | Greasing of agitators, motor & pumps | Quarterly | RP20 | Q 3 |
| 17 | Dismantling & assembling of after cooler & moisture separator of both air compressors | Half Year | AC6,AC7 | HY1 |
| 18 | Clean out water jacket of NH3 & Air compressors | Half Year | RP20 | HY2 |
| 19 | Air purging of refrigeration plant | Monthly | RP21 | M4 |
| 20 | Cleaning of condensor water tank | Quarterly | RP22 | Q4 |
| 21 | Complete overhauling of Air compressor | Yearly | AC8,AC9 | Y1 |
| 22 | Complete overhauling of Ammonia compressors | Yearly | AC23,AC24,25 | Y2 |
| 23 | Overhauling and painting of agitators | Yearly | RP26 | Y3 |
| 24 | Overhauling of chilled water pumps | Yearly | RP27,28,29 | Y4 |
| 25 | Overhauling of condensor water pumps | Yearly | RP30,31,32 | Y5 |
| 26 | Overhauling of diffusers | Yearly | RP33 TO 37 | Y6 |
| 27 | Overhauling of under ground water tanks pump | Yearly | RP38 to 40 | Y7 |
| Prepared by H O D | | Approved by CEO | | |
| Signature _____ Date 01.04.04 | | Signature _____ Date 01.04.04 | | |
| Issue No. 01 Date 01.04.04 | | Revision No. 0 Date 01.04.04 | | |

[QMMRP-03]

| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. | | PAGE NO. 10 | |
|---|---|-------------------------------|-----------|
| TITLE :- DEPARTMENTAL PROCEDURES ENGINEERING | | DATE :- 01.04.04 | |
| INSTRUMENTS CHECKS / CALIBRATION SCHEDULE FOR MONITORING THE ACCURACY OF INSTRUMENTS | | | |
| ANNEXURE - F | | | |
| SR. NO. | JOB DESCRIPTION | JOB CODE | FREQUENCY |
| I | STANDARD / TEST INSTRUMENTS TO counter check the calibration of standard / testing instruments from approved laboratory e.g. N.P.L etc. | Y | YEARLY |
| 2 | PROCESS CONTROLS : ----> | | |
| a | Calibration of temperature gauges | M1 | MONTHLY |
| b | Calibration of pressure gauges | M2 | MONTHLY |
| c | Calibration of PID controller | M3 | MONTHLY |
| d | Calibration of FDV controller | M4 | MONTHLY |
| e | Calibration of thermographs | M5 | MONTHLY |
| II | POWDER PLANT CONTROLS :- | | |
| a | Calibration of temperature gauges | M6 | MONTHLY |
| b | Calibration of pressure gauges | M7 | MONTHLY |
| c | Calibration of PID controller | M8 | MONTHLY |
| d | Calibration of vaccum gauges | M9 | MONTHLY |
| e | Calibration of thermographs | M10 | MONTHLY |
| f | Calibration of drought gauges | M11 | MONTHLY |
| g | Calibration of pressure transmitter | M12 | MONTHLY |
| h | Calibration of digital temp. indicators | M13 | MONTHLY |
| III | QUALITY ASSURANCE (MAIN LAB.) | | |
| a | Calibration of pressure gauges | M14 | MONTHLY |
| b | Calibration of digital temp. indicators | M15 | MONTHLY |
| c | Calibration of IR balance | M16 | MONTHLY |
| | SERVICES | | |
| IV | BOILER CONTROLS :----> | | |
| a | Calibration of digital indicators | M17 | MONTHLY |
| b | Calibration of pressure gauges | M18 | MONTHLY |
| c | Calibration of drought gauges | M19 | MONTHLY |
| V | REFRIGRATION | | |
| a | Calibration of compound gauges | M20 | MONTHLY |
| b | Calibration of pressure gauges | M21 | MONTHLY |
| c | Calibration of temp. gauges | M22 | MONTHLY |
| VI | D.G.SET CONTROLS | | |
| a | Speed indicator | D | DAILY |
| b | Lub. oil pressure gauges | D | DAILY |
| c | Fuel oil pressure gauges | D | DAILY |
| d | Water temp. indicator | D | DAILY |
| e | Battery charging indication | D | DAILY |
| f | Air filter indicators | D | DAILY |
| VII | WEIGHTING SCALES | | |
| a | Calibration of electronic / mechanical weighting scales | W1 | WEEKLY |
| b | Calibration of weigh bridge | W23 | MONTHLY |
| Prepared by H O D | | Approved by CEO | |
| Signature _____ Date 01.04.04 | | Signature _____ Date 01.04.04 | |
| Issue No. 01 Date 01.04.04 | | Revision No. 0 Date 01.04.04 | |

[QMMRP-03]

LIST OF CRITICAL EQUIPMENTS

| SR.NO. | SECTION | EQUIPMENT |
|--------|---------------|---|
| A | EVAPORATOR | I VACCUM PUMP NO-1 II VACCUM PUMP NO-2 |
| B | DRIER | I ROTO PUMP II EXHAUST FAN III SUPPLY FAN IV P.C. FAN V ATOMISER |
| C | PROCESSING | I CREAM SEPRATOR NO-1 II CREAM SEPRATOR NO-2 III CREAM SEPRATOR NO-3 |
| D | BUTTER & GHEE | I BUTTER CHURN NO-1 II BUTTER CHURN NO-2 III POUCH FILLING MACHINE |
| E | LIQUID MILK | I POUCH FILLING MACHINE NO-1 II POUCH FILLING MACHINE NO-2 III POUCH FILLING MACHINE NO-3 |
| F | BOILER | I I.D. FAN II F.D. FAN NO-1 III F.D. FAN NO-2 IV FEED WATER PUMP NO-1 V FEED WATER PUMP NO-2 |
| G | REFRIGERATION | I NH3. COMPRESSOR NO-1 II NH3. COMPRESSOR NO-2 III NH3. COMPRESSOR NO-3 IV AIR COMPRESSOR NO-1 V AIR COMPRESSOR NO-2 VI SUBMERSIBLE PUMP |
| H | ELECTRICAL | I D.G. NO-1 II D.G. NO-2 III TRANSFORMER 2000KVA |

Prepared by HOD | Approved By CEO

Signature _____ Date 01.04.04 | Signature _____ Date 01.04.04

Issue No. 01 | Date 01.04.04 | Revision No. 0 | Date 01.04.04

ANNEXURE - 'H'

LIST OF LUBRICANTS TO BE USED

| S.NO. | DESCRIPTION | USING MACHINE |
|-------------------|------------------------------|--|
| | SERVO SYSTEM - 32 | LUBRICATION OF ATOMIZER BEARINGS |
| | SERVO MESH - 150 | AIR COMPRESSORS |
| | SERVO MESH - 220 | CREAM SEPARATORS, BUTTER CHURNS GHEE CLEARIFIER, GEAR BOXES |
| | SERVO FREEZE - 68 | AMMONIA COMPRESSORS |
| | CASTROL ENGINE OIL - 15 W/40 | DIESEL GENERATOR SETS |
| | GREASE -AP-3 | BEARINGS OF OTHER PLANT & MACHINERY (NOT SPECIFICALLY MENTIONED BY MANUFACTURER (SUPPLIER) |
| Prepared by H O D | | Approved by CEO |
| Signature | Date 01.04.04 | Signature _____ Date 01.04.04 |
| Issue No. 01 | Date 01.04.04 | Revision No 0 Date 01.04.04 |

[QMMRP - 03]

ANNEXURE - ' I '

SPECIFICATIONS FOR ETP'S WATER

| S.NO. | PARTICULARS | DESIRED NORMS |
|-------------------------------|-----------------|-------------------------------|
| I | PH | 7 - 9 |
| II | Suspended solid | Not more than 100 PPM |
| III | COD | Not more than 250 PPM |
| IV | BOD | Not more than 30 PPM |
| V | Oil & Grease | Not more than 10 PPM |
| Prepared by H O D | | Approved by CEO |
| Signature _____ Date 01.04.04 | | Signature _____ Date 01.04.04 |
| Issue No. 01 Date 01.04.04 | | Revision No 0 Date 01.04.04 |

[QMMRP - 03]

| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. | | | | PAGE NO. 13 B | |
|---|--|--|-----------------|-----------------------------------|------------------|
| TITLE :- DEPARTMENTAL PROCEDURES ENGINEERING | | | | DATE :- 01.04.04 | |
| INNOVATIVE BUSINESS OMPROVEMENTS (PVT.) LTD. PREVENTIVE MAINTENANCE SCHEDULE OF D.G. SET | | | | | |
| " ANNEXURE J " | | | | | |
| SR NO. | SERVICE ITEMS | SERVICE METER UNITS (RUNNING HRS.) [SMU] | UNITS GENERATED | ATTENDED BY | SECTION INCHARGE |
| 01 | DAILY CHECKS :- & AFTER EVERY 50 HRS. i) Check that fuel tank is filled up ii) Drain sediments and water from fuel tank and water separator iii) Check the engine oil level from dipstick iv) Check the Engine coolant level v) Check air cleaner service Indicator vi) Check the loose or broken fittings guard's and components vii) Inspect for worn/broken and loose belts viii) Check the battery connections and maintain electrolyte level ix) Check the condition of all gauges, repair or replace any broken gauge x) Check the exhaust manifold or air piping leakage | 50 HRS. | | | |
| 02 | CHANGE THE FOLLOWING PARTS AT EVERY 250 HRS i) Change the lubrication oil. lubricating oil (Rx super plus) 15w/40 of castrol make) ii) Change the lubrication oil filters iii) Change the fuel filters iv) Change/wash the fuel separator filter v) Wash the primary fuel filter vi) Check the vibration mounting vii) Clean the radiator externally viii) Add the 2.500ltr. of intac liquid coolant in the radiator ix) Check all hoses of the engine | 250 HRS. | | | |
| 03 | Check and adjust the tappet clearance | 2000 HRS | | | |
| Prepared by H O D | | | | Approved by CEO | |
| Signature _____ Date 01.04.04 | | | | Signature _____ Date 01.04.04 | |
| Issue No. 01 Date 01.04.04 | | | | Revision No. 0 Date 01.04.04 | |

[QMMRP - 03]

| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. | | PAGE NO 14 | |
|--|--|-------------------------------|--------------|
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | | DATE . 01.04.04 | |
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. | | | |
| INSTRUMENTS CHECK / CALIBRATION SCHEDULE FOR MONITORING THE ACCURACY OF INSTRUMENTS | | | ANNEXURE - J |
| SR.NO | JOB DESCRIPTION | CODE | FREQUENCY |
| I | PROCESS CONTROLS : ---> | | |
| a | Checking of temp. gauges | D | DAILY |
| b | Cleaning of gauges glass inside and out side | D | DAILY |
| c | Calibration of temp gauges in case of deviation it should be rechecked & displayed | F1 | FORTNIGHTLY |
| d | To counter check the calibration of standard temp gauge instrument from approved laboratory e.g. NPL etc | Y | YEARLY |
| II | PASTEURISER CONTROLLER :- | | |
| a | Checking of controls working | D | DAILY |
| b | Checking of thermographs & ink pens | D | DAILY |
| c | Checking of air pressure gauges | D | DAILY |
| d | Checking of air pressure regulator and the sensor | D | DAILY |
| e | Check the sensor when not in use | D | DAILY |
| f | Calibration of PID controller | F2 | FORTNIGHTLY |
| III | POWDER PLANT CONTROLS :- | | |
| a | checking of all digital indicators | D | DAILY |
| b | Checking of vacuum gauges | D | DAILY |
| c | Check & Tighten the Simplex and Duplex Sensors | D | DAILY |
| d | Caliberation of all digital indicators | F3 | FORTNIGHTLY |
| | SERVICES | | |
| IV | BOILER CONTROLS :---> | | |
| | Check | | |
| a | Temp.controller of Bed No I | D | DAILY |
| b | Temp.Indicator of Bed No I | D | DAILY |
| c | Temp.controller of Bed No II | D | DAILY |
| d | Temp.Indicator of Bed No II | D | DAILY |
| e | Main Steam Pressure ofBoiler | D | DAILY |
| f | Steam Pressure at Main Header | D | DAILY |
| g | Draught gauge of FD Fan No I | D | DAILY |
| h | Draught gauge of FD Fan No II | D | DAILY |
| i | Steam Pressure of PRV Station | D | DAILY |
| j | Caliberation of temperature controllers of boiler | F4 | FORTNIGHTLY |
| V | D.G.Set CONTROLS D.G. SET - 1 | | |
| | Check | | |
| a | Speedometer gauge | D | DAILY |
| b | Lub.Oil pressure | D | DAILY |
| c | Fuel pressure | D | DAILY |
| d | Water Temp. Indicator | D | DAILY |
| e | Battery charging indication | D | DAILY |
| VI | D.G.Set-2 | | |
| a | Speedometer gauge | D | DAILY |
| b | Lub.Oil pressure | D | DAILY |
| c | Fuel pressure | D | DAILY |
| d | Water Temp. Indicator | D | DAILY |
| e | Battery charging indication | D | DAILY |
| VI | WEIGHING SCALES | | |
| a | Checking of Electronic Weighing Scales | W1 | WEEKLY |
| | Checking of Weighing Scales Bridge | W2 | WEEKLY |
| Prepared by H O D | | Approved by CEO | |
| Signature _____ Date 01.04.04 | | Signature _____ Date 01.04.04 | |
| Issue No. 01 Date 01.04.04 | | Revision No. 0 Date 01.04.04 | |

[QMMRP - 03]

| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. | | PAGE NO. 15 |
|--|-------------------------------|-----------------------------------|
| TITLE:- DEPARTMENTAL PROCEDURES ENGINEERING | | DATE :01.04.04 |
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. MAINTENANCE REPORT (GENERAL) | | " ANNEXURE K " |
| MILK CHILLING CENTRE : ----- | | |
| VISIT NO. _____ | | |
| DATED _____ DATE OF LAST VISIT _____ | | |
| S.NO | JOB DESCRIPTION | STATUS |
| 1 | MILK PIPE LINES AND FITTINGS | O.K./LEAKING |
| 2 | WATER PIPE LINE AND FITTINGS | O.K./LEAKING |
| 3 | MILK PUMP (....NOS) | O.K. /DEFECTIVE |
| 4 | MILK STORAGE TANK ACCESSORIES | O.K. /DEFECTIVE |
| 5 | WATER PUMPS (.....NOS) | O.K. /DEFECTIVE |
| 6 | CONDITION OF BUILDINGS | |
| | A) MACHINERY WORK | O.K./NEEDS REPAIRS |
| | B) SANITARY PIPE FITTINGS | O.K./NEEDS REPAIRS |
| | C) CARPENTARY/JOINERY WORKS | O.K./DEFECTIVE |
| | D) PAINTING / WHITEWASHING | O.K./DEFECTIVE |
| 07 | CONDITION OF DISPOSAL WORK | O.K. /NEED PAINTAING |
| 08 | REPAIRS CARRIED OUT | |
| 09 | MATERIAL REQUIRED FOR REPAIRS | |
| TECHNICIAN ZONE INCHARGE | | H O D (Engineering) |
| Prepared By H O D | | Approved by CEO |
| Signature _____ Date 01/08.2003 | | Signature _____ Date 01.04.04 |
| Issue No. 01 Date 01/08.2003 | | Revision No. 0 Date 01.04.04 |

[QMMRP - 03]

| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. | | | PAGE NO. 16 | | | | |
|--|--|------------------------------|---------------------------|-------------------------------|-------------------------------|----------------|-------------------------------|
| TITLE:- DEPARTMENTAL PROCEDURES ENGINEERING | | | DATE :01.04.04 | | | | |
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. MAINTENANCE REPORT (ELECTRICAL) " ANNEXURE - L " | | | | | | | |
| MILK CHILLING CENTRE : ----- | | | | | | | |
| VISIT NO. _____ | | | DATE OF LAST VISIT: _____ | | | | |
| DATE: _____ | | | | | | | |
| SR. NO. | JOB DESCRIPTION | | CHILLED WATER PUMP | MILK PUMP | MILK STORAGE TANK AGITATOR | GENERATING SET | DOMESTIC FITTINGS/ APPLIANCES |
| 1 | Voltage | Volts | | | | | |
| 2 | Current | Amps. | | | | | |
| 3 | Insulation Resistance | O.K. / WEEK | | | | | |
| 4 | Condition of Bearings | O.K./ Defective | | | | | |
| 5 | Running temperature | Normal/ abnormal | | | | | |
| 6 | Running sound | Normal/ abnormal | | | | | |
| 7 | Capacity of fuses | Amps. | | | | | |
| 8 | Relay setting | Amps. | | | | | |
| 9 | Earthing | O.K. /Done | | | | | |
| 10 | Clean & tighten all terminals/ contracts | O.K. /Done | | | | | |
| 11 | General Conditions | Satisfactory/ Unsatisfactory | | | | | |
| TECHNICIAN | | | ZONE INCHARGE | | H. O. D. (ENGINEERING) | | |
| Prepared By H O D | | | | Approved by CEO | | | |
| Signature _____ Date 01.04.04 | | | | Signature _____ Date 01.04.04 | | | |
| Issue No. 01 Date 01.04.04 | | | | Revision No. 0 Date 01.04.04 | | | |

[QMMRP - 03]

INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD.
 ANNUAL MAINTENANCE SCHEDULE

| DATE OF ACTION | SECTION | EQUIPMENTS | PARTS DESCRIPTION | PART POSITION | PART REPLACED | M/C OPENED BY | M/C FITTED BY | SIGN.OF EXE. TECH. | ANNEXURE - 'M' | | REMARKS |
|----------------|---------|------------|-------------------|---------------|---------------|---------------|---------------|--------------------|-----------------------------|--|---------|
| | | | | | | | | | SIGN.OF PRODUCTION INCHARGE | | |
| | | | | | | | | | | | |

Prepared By **H O D** Approved by CEO
 Signature _____ Date 01.04.04 Signature _____ Date 01.04.04
 Issue No. 01 Date 01.04.04 Revision No. 0 Date 01.04.04

| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. | | PAGE NO | 18 |
|---|--------------------------------------|---|-------------|
| TITLE : DEPARTMENTAL PROCEDURES ENGINEERING | | DATE : | 01.04.04 |
| Norms for Prime Performance Parameters | | | |
| ANNEXURE - 'N' | | | |
| SR. NO. | DESCRIPTION | SUMMER | WINTER |
| i) | Fuel utilisation efficiency | 80% | 90% |
| ii) | Power utilisation efficiency | 80% | 90 % |
| iii) | Maintenance cost / litre of Milk | 0.0288 | 0.02 |
| iv) | Product down time | Nil | Nil |
| v) | Expenditure on printing (Stationary) | Rs. 300/- | Rs. 300 /- |
| vi) | Expenditure on staff welfare | Rs. 300/- | Rs. 300 /- |
| vii) | Expenditure on civil work | Rs.2000/- | Rs. 2000 /- |
| viii) | Expenditure on Liveries | Rs.1000/- | Rs. 1000 /- |
| ix) | Expenditure on testing fee etc. | Rs. 500/- | Rs. 500 /- |
| x) | Expenses on travelling | Rs.1000/- | Rs. 1000 /- |
| Prepared by H O D | | Approved by CEO | |
| Signature _____ Date 01.04.04 | | Signature _____ Date 01.04.04 | |
| Issue No. 01 Date 01.04.04 | | Revision No. Date 01.04.04 | |

[QMMRP - 03]

| SR. NO | ACT/RULES | SEC/RULE | ACTIVITY | COMPLIANCE | PERIODICITY | TIME LIMIT | RESPONSIBILITY | CONSEQUENCIES IN FAILURE | ORIGINAL DOCUMENTS IN WHOSE CUSTODY | ANNEXURE - 'P' FILE NAME WITH LOCATION |
|--------|--|--------------------|--|---|--------------------------|-------------------------|----------------|---|-------------------------------------|---|
| 1 | WEIGHT & MEASURES ACT-1985 | Rule - 22 | (RE-VERIFICATION & STAMPING OF WEIGHTS/ SCALES STAMPING & CALIBRATION) | Calibration of all weigh scales Filling M/cs, Bottle filler weigh bridge, dead weights bullion weight, fractional weights | ANNUAL | FEB / MAR | HOD ENGG | Compounding before the Asisst. controller of Legal Metrology Patiala division and further complaint before jurisdictional magistrate. | ENGG.DEPTT | MSL/ENGG/F/W&M-10 MSL/ENGG/FC-01/C-02 |
| 2 | CHIEF ELECTRICAL INSPECTOR | RULE 46 IER - 1956 | INSPECTION OF DG SETS & TRANSFORMERS | Safety and Earthing of all equipment to be carried out. | ANNUAL | JULY | - DO - | STOPPING OF ELECTRICITY | ENGG.DEPTT | MSL/ENGG/F/CEI-18 MSL/ENGG/FC-01/C-02 |
| 3 | INDIAN FACTORY ACT | SEC -31 | EXAMINATION & TESTING OF PRESSURE VESSELS | 1. Ultrasonic test of all pressure vessels / repair of lifting machines 2. Hydraulic testing of pressure vessels | ANNUAL 4 years. | BEFORE 16 JULY | - DO - | PROSECUTION | PNL & HRD | MSL/ENGG/F/PD-03 MSL/ENGG/FC-01/C-02 |
| 4 | INDIAN BOILER ACT-1923 (ACT-V OF 1923) | SEC-7 & 8 | EXAMINATION OF BOILER | Hydraulic testing, safety valves working | ANNUAL | SEPT | - DO - | STOPPING OF BOILER | ENGG.DEPTT | MSL/ENGG/F/BCI-01 MSL/ENGG/FC-01/C-01 |
| 5 | PREVENTION & CONTROL OF POLLUTION 1977 | | WATER CESS RETURN | Water consumption send to environmental engineer PPCB through duly filled form 1-A | MONTHLY | 1ST WEEK OF EVERY MONTH | - DO - | SUB SEC-1(A) OF SECTION 60 | ENGG.DEPTT | MSL/ENGG/F/WC-04A MSL/ENGG/FC-01/C-01 |
| 6 | U/S 25/26 OF WATER ACT-1974 | | WATER CONSENT | To maintain ETP effluent water as per PPCB norms | 15 YEARS TILL 31.03.2011 | 01.04.2011 | - DO - | STOPPING OF PLANT | HEAD OFFICE | MSL/ENGG/F/PPCB-04 MSL/ENGG/FC-01/C-01 |
| 7 | U/S 21 OF AIR ACT 1981 | | AIR CONSENT | To control air pollution (Flue gases from boiler chimney) as per PPCB norms | - DO - | 01.04.2011 | - DO - | - DO - | HEAD OFFICE | -- DO -- |

Prepared by **H O D** Approved by **CEO**
 Signature Date 01.04.04 Signature Date 01.04.04
 Issue No 01 Date 01.04.04 Revision No. 0 Date 01.04.04

INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. PAGE NO 20

TITLE : DEPARTMENTAL PROCEDURES ENGINEERING DATE : 01.04.04

ANNEXURE - 'Q'

ANNUAL MAINTENANCE CONTRACT

| SR NO | DESCRIPTION | DATE OF EXPIRY | ACTON TO BE INITIATED | RESPONSIBLE PERSON |
|-------|-----------------------------------|----------------|-----------------------|--------------------|
| 1 | Weigh bridge / Mechanical balance | 31.12.2003 | 1st December | H. O. D. (Engg) |
| 2 | Electronic Balance | 30.04.2004 | 1st April | -- d o -- |
| 3 | Motor rewinding | 14.07.2004 | 1st May | -- d o -- |
| 4 | EPABX | 23.03.2004 | 1st March | -- d o -- |

| | |
|---------------------------------|---------------------------------|
| Prepared by H O D | Approved by CEO |
| Signature _____ Date : 01.04.04 | Signature _____ Date : 01.04.04 |
| Issue No. 01 Date : 01.04.04 | Revision No. 0 Date : 01.04.04 |

[QMMRP - 03]

INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD.

**Engineering Department
Implementation Tasks**

Page 1 of 7
Annexure – 'N'

Objective: Reducing production breakdowns, downtime and maintenance expenditure.

| SR NO | IMPLEMENTATION TASK | IMPLEMENTATION BY | MONITORING BY |
|---------------------------|--|--------------------------|----------------------|
| ELECTRICAL SECTION | | | |
| 1. | Ensure proper lubrication and preventive maintenance of equipment as per schedules. | Sr. Electrician | H O D |
| 2. | Use lubricants of good quality / correct specifications. | Sr. Electrician | H O D |
| 3. | Components causing frequent breakdowns to machinery should be replaced with better quality. | Sr. Electrician | H O D |
| 4. | Use better quality spares. | Sr. Electrician | H O D |
| 5. | Always use proper tools for maintenance of dairy equipment. | Sr. Electrician | H O D |
| 6. | Carry out preventive maintenance of elect. motors on periodic basis to reduce motors getting brunt. | Sr. Electrician | H O D |
| 7. | Install electric motors as per load conditions. | Sr. Electrician | H O D |
| 8. | Proper capacity fuses / over load protection units should be provided with all electrical installations. | Sr. Electrician | H O D |
| 9. | Power factor must be maintained at the appropriate level to avoid damage to machinery and reduce power bill. | Sr. Electrician | H O D |
| 10. | Motors should be periodically cleaned to remove dust by using blower / brush. | Sr. Electrician | H O D |
| 11. | Install best quality electrical appliances and controls. | Sr. Electrician | H O D |
| 12. | Switch of electrical appliances when not in use. | Sr. Electrician | H O D |
| 13. | Avoid using poor quality of light fixtures that consume more electricity. | Sr. Electrician | H O D |
| 14. | Ensure cleaning of light fixtures weekly. | Sr. Electrician | H O D |

INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD.

**Engineering Department
Implementation Tasks**

Page 2 of 7
Annexure – 'N'

Objective: Reducing production breakdowns, downtime and maintenance expenditure.

| SR NO | IMPLEMENTATION TASK | IMPLEMENTATION BY | MONITORING BY |
|--------------|---|--------------------------|----------------------|
| 15. | Ensure that fluorescent tubes are used in place of bulbs. | Sr. Electrician | H O D |
| 16. | Use generators only when absolutely necessary. | Shift Electrician | H O D |
| 17. | Install auto on / off control switch for campus lighting. | Sr. Electrician | H O D |
| 18. | Launch awareness campaign to save electricity by all possible means. | Sr. Electrician | H O D |
| 19. | Maintain separate circuit switches for essential and not so important illumination points. | Sr. Electrician | H O D |
| 20. | Explore innovate energy conservation techniques using collective wisdom of available manpower. | Sr. Electrician | H O D |
| 21. | Carry out servicing of DG set after every 250 running hours. | Sr. Electrician | H O D |
| 22. | Reduce the peak hours load from 400 K.W to 150 KW during summer season or as and when required. | Sr. Electrician | H O D |
| 23. | Carry out proper maintenance of HT lines. | Sr. Electrician | H O D |
| 24. | Check amperes of each motor periodically for assessing actual being drawn. | Sr. Electrician | H O D |
| 25. | To monitor power utilisation / consumption pattern on daily basis. | Sr. Electrician | H O D |
| 26. | Keep the connected load of factory as low as possible. | Sr. Electrician | H O D |
| 27. | Keep automatic controls of pasteurizer & other machines in working order to reduce electricity consumption. | Sr. Electrician | H O D |
| 28. | Allot specific duties to specific staff so as to switch off the lights and fixtures when not in use. | Sr. Electrician | H O D |

INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD.

Engineering Department
Implementation Tasks

Page 3 of 7
Annexure – 'N'

Objective: Reducing production breakdowns, downtime and maintenance expenditure.

| SR NO | IMPLEMENTATION TASK | IMPLEMENTATION BY | MONITORING BY |
|-------|---|-------------------|---------------|
| 29. | Run exhaust fans only when required. | Plant Operators | Mgr. (P) |
| 30. | Switch off pesto-flash units during night hours. | SI / Exec. / AM | Mgr. (P) |
| 31. | Exhaust fan for sweeping powder from the chamber be run only for ten to fifteen minutes after stoppage of powder plant. | P. Plant Operator | Mgr. (P) |
| 32. | Use only one spray pond pump for running of powder plant. | SI / Exec. / AM | HOD |
| 33. | Avoid reprocessing of milk and milk products to save power. | P. Plant Operator | Mgr. (P) |

INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD.

**Engineering Department
Implementation Tasks**

Page 4 of 7
Annexure – 'N'

Objective: Reducing production breakdowns, downtime and maintenance expenditure.

| SR NO | IMPLEMENTATION TASK | IMPLEMENTATION BY | MONITORING BY |
|------------------------------|---|------------------------|---------------|
| REFRIGERATION SECTION | | | |
| 34. | Ensure proper lubrication and preventive maintenance of equipment as per specified. | Jr. Foreman | H O D |
| 35. | Components causing frequent breakdowns to machinery should be replaced with better quality parts. | Jr. Foreman | H O D |
| 36. | Use better quality spares. | Jr. Foreman | H O D |
| 37. | Use always proper tools for proper fitting of equipment. | Jr. Foreman | H O D |
| 38. | Check that oil is drained from oil separators in each shift. | Operator / Jr. Foreman | H O D |
| 39. | Leak test of refrigeration equipment must be carried out on daily basis to ensure that pipelines are not leaking. | Operator / Jr. Foreman | H O D |
| 40. | Ensure proper insulation of heat transfer surfaces to save power. | Jr. Foreman | H O D |
| 41. | Avoid reprocessing of milk and milk products to save power. | Jr. Foreman | H O D |
| 42. | Keep the operational hours of refrigeration / compressors as low as possible. | Jr. Foreman | H O D |
| 43. | Closely monitor the temperature of cold store. Ensure defrosting of ice cream cold store regularly. | Jr. Foreman | H O D |
| 44. | Check that ammonia compressors are being operated as per specified parameters. | Operator / Jr. Foreman | H O D |
| 45. | Ensure that condenser coils are cleaned on periodic basis. | Jr. Foreman | H O D |

INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD.

**Engineering Department
Implementation Tasks**

Page 5 of 7
Annexure – 'N'

Objective: Reducing production breakdowns, downtime and maintenance expenditure.

| SR NO | IMPLEMENTATION TASK | IMPLEMENTATION BY | MONITORING BY |
|-----------------------|---|--------------------------|----------------------|
| BOILER SECTION | | | |
| 46. | Ensure proper lubrication and preventative maintenance of equipment as per schedule. | Foreman | H O D |
| 47. | Components causing frequent breakdowns to machinery should be replaced with better quality parts. | Foreman | H O D |
| 48. | Use better quality spares. | Foreman | H O D |
| 49. | Use always proper tools for proper fitting of equipment. | Tech. | Foreman |
| 50. | Ensure that good quality valves are used in boiler department to avoid loss of steam due to leakages. | Foreman | H O D |
| 51. | Optimise efficiency of the steam raising equipment and utilization of steam. | Foreman | H O D |
| 52. | Explore innovate energy conservation techniques using collective wisdom available manpower. | Foreman | H O D |
| 53. | Ensure correct weightment and accurate testing of husk when received in plant. | Boiler Attendant | H O D |
| 54. | Monitor daily consumption and efficiency of fuel utilisation. | H O D (Engg) | GM (W) |
| 55. | Employ competent boiler operators and maintenance techniques. | H O D (Engg) | GM (W) |
| 56. | Always keep fire and water side of boiler perfectly clean and feed only soft water to boiler. | Boiler Attendant | Foreman |
| 57. | Regulate draught and monitor temperature of out going gases to maintain efficiency of steam generation. | Boiler Attendant | Foreman |
| 58. | Ensure proper heating temperature of feed water. | Boiler Attendant | Foreman |

INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD.

**Engineering Department
Implementation Tasks**

Page 6 of 7
Annexure – 'N'

Objective: Reducing production breakdowns, downtime and maintenance expenditure.

| SR NO | IMPLEMENTATION TASK | IMPLEMENTATION BY | MONITORING BY |
|--------------|---|--------------------------|----------------------|
| 59. | Utilize condensate of evaporating plant as feed water taking precautions to avoid mixing of milk with feed water. | Foreman | H O D |
| 60. | Reduce operational hours of boiler by proper scheduling of processing operations. | Manager (Prod.) | GM (W) |
| 61. | Ensure that moisture free and good quality charcoal is used. | Boiler Attendant | Foreman |
| 62. | Do not operate boiler at pressures less than 6 kg / cm ² and more than working pressure. | Boiler Attendant | Foreman |
| 63. | Ensure that steam pipelines & fittings are well insulated and remain free from leakage. | Boiler Attendant | H O D |
| 64. | Ensure that steam traps are working properly. | Boiler Attendant | Foreman |
| 65. | Ensure that steam valves are not leaking. | Boiler Attendant | Foreman |
| 66. | Ensure that desired steam pressure is maintained at different operational parameters to save fuel. | Boiler Attendant | Foreman |
| 67. | Utilization of steam condensate water of different equipment namely pasteurizer, ghee kettle & sterilizer etc. for different purposes in the factory. | Foreman | H O D |
| 68. | Ensure that live steam is not wasted / misused. | Boiler Attendant | Foreman |

INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD.

**Engineering Department
Implementation Tasks**

Page 7 of 7
Annexure – ‘N’

Objective: Reducing production breakdowns, downtime and maintenance expenditure.

| SR NO | IMPLEMENTATION TASK | IMPLEMENTATION BY | MONITORING BY |
|----------------------------|---|--------------------------|----------------------|
| MAINTENANCE SECTION | | | |
| 69. | Ensure proper lubrication and preventive maintenance of equipment as per schedule. | Foreman | H O D |
| 70. | Impart proper training to plant operators. | Foreman | H O D |
| 71. | Allot specific machines to specific plant operators to avoid chances mishandling / breakdowns. | Manager (Prod.) | GM (W) |
| 72. | Use good quality / correct specifications lubricants. | Foreman | H O D |
| 73. | Allot daily lubrication work to specific operators / technicians. | Foreman | H O D |
| 74. | Take preventive measures to avoid corrosion of metal parts. | Foreman | H O D |
| 75. | Components causing frequent breakdowns to machinery should be replaced with better quality parts. | H O D | H O D |
| 76. | Use better quality spares. | Foreman | H O D |
| 77. | Use always proper tools for proper tools for proper fitting of equipment. | Tech. | Foreman |
| 78. | Get daily certificate from foreman / senior technician that machinery installed in their section is in perfect working condition. | Foreman | H O D |
| 79. | Upgrade processes, systems and technology to save energy consumption. | Foreman | H O D |
| 80. | Keep automatic controls of pasteurizers & other machines in working order. | Foreman | H O D |
| 81. | Organise and implement concept of MBO and develop effective system for monitoring. | Foreman | H O D |
| 82. | Provide steam only on limited numbers of wash points. | Foreman | H O D |
| 83. | Ensure that pasteurizers are run on full capacity. | Foreman | H O D |

TITLE:- DEPARTMENTAL PROCEDURES QUALITY ASSURANCE

LOG SHEET FOR REFRIGERATION PLANT

DATE :-

| HOURS | COMPRESSOR NO. 1 | | COMPRESSOR NO. 2 | | COMPRESSOR NO. 3 | | AIR COMPRESSOR | | IBT | | IBT | | CHILLED WATER PUMP RUNNING | | CONDENSOR WATER PUMP RUNNING | | WATER SUPPLY PUMP | | | | OPERATOR'S SIGNATURE | REMARKS/OBSERVATIONS | | |
|-------|------------------|----|------------------|-----|------------------|----|----------------|-----|-----|-----|-----|------|----------------------------|------|------------------------------|-----|-------------------|-----|------|-----|----------------------|----------------------|-----|-----|
| | LP | HP | OP | AMP | LP | HP | OP | AMP | OP | AMP | NO | TEMP | NO | TEMP | NO | NO. | NO. | NO. | TUBE | R.W | | | R.W | R.W |
| 6 AM | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 AM | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 AM | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 AM | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 AM | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 AM | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 AM | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 PM | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 PM | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 PM | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 PM | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 PM | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 PM | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 PM | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 PM | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 PM | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 PM | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 PM | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 PM | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 AM | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 AM | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 AM | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 AM | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 AM | | | | | | | | | | | | | | | | | | | | | | | | |

LEGEND : LP - LOW SUCTION PRESSURE TEMP - TEMPERATURE
 HP - HIGH DISCHARGE PRESSURE R.W. - RAW WATER
 OP - OIL PRESSURE IBT - ICE BANK TANK
 AMP - AMPERES

JUNIOR FORMAN
 SIGNATURE : _____

H.O.D.(Engineering)
 SIGNATURE : _____

Prepared By **HOD**

Approved by CEO

Signature _____ Date 01.04.04
 Issue No. 01

Signature _____ Date 01.04.04
 Revision No. 0

INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD.
 LOG SHEET FOR ICE CREAM REFRIGERATION PLANT

DATE:

| HOURS | BOOSTER NO. 1 | | BOOSTER NO. 2 | | COMPRESSOR NO. 1 | | COMPRESSOR NO. 2 | | ICE CREAM COLD STORE TEMP. | BRINE TANK TEMP. | | COND. WATER PUMPS. | | OPERATOR'S SIGNATURE | REMARKS/OBSERVATIONS |
|-------|---------------|----|---------------|----|------------------|----|------------------|----|----------------------------|------------------|----|--------------------|----|----------------------|----------------------|
| | LP | HP | LP | HP | LP | HP | LP | HP | | I | II | I | II | | |
| 6 AM | | | | | | | | | | | | | | | |
| 7 AM | | | | | | | | | | | | | | | |
| 8 AM | | | | | | | | | | | | | | | |
| 9 AM | | | | | | | | | | | | | | | |
| 10 AM | | | | | | | | | | | | | | | |
| 11 AM | | | | | | | | | | | | | | | |
| 12 AM | | | | | | | | | | | | | | | |
| 1 PM | | | | | | | | | | | | | | | |
| 2 PM | | | | | | | | | | | | | | | |
| 3 PM | | | | | | | | | | | | | | | |
| 4 PM | | | | | | | | | | | | | | | |
| 5 PM | | | | | | | | | | | | | | | |
| 6 PM | | | | | | | | | | | | | | | |
| 7 PM | | | | | | | | | | | | | | | |
| 8 PM | | | | | | | | | | | | | | | |
| 9 PM | | | | | | | | | | | | | | | |
| 10 PM | | | | | | | | | | | | | | | |
| 11 PM | | | | | | | | | | | | | | | |
| 12 PM | | | | | | | | | | | | | | | |
| 1 AM | | | | | | | | | | | | | | | |
| 2 AM | | | | | | | | | | | | | | | |
| 3 AM | | | | | | | | | | | | | | | |
| 4 AM | | | | | | | | | | | | | | | |
| 5 AM | | | | | | | | | | | | | | | |
| TOTAL | | | | | | | | | | | | | | | |
| HRS. | | | | | | | | | | | | | | | |

COMU HP - HIGH DISCHARGE PRESSURE JR. FOREMAN SIG: _____ H.O.D. (ENGG.)
 OP - OIL PRESSURE
 LP - LOW SUCTION PRESSURE
 HRS. Signature _____ Date 01.04.04
 Approved by CEO
 Signature _____ Date 01.04.04
 Issue No. 01 Date 01.04.04 Revision No. 0 Date 01.04.04

DAILY LOG SHEET (ELECTRICAL)

| TIME HOURS | HT AMPS | LT AMPS | LT AMPS | P.F. | SECTION | ENERGY METER READING AT 6:00 A.M. | TODAY'S READING | PREVIOUS DAY READING | CONSUMPTION IN 24 HRS. | REMARKS |
|------------|---------|---------|---------|------|---------------------------|-----------------------------------|-----------------|----------------------|------------------------|---|
| | | | | | | | | | | |
| 7 AM | | | | | (A) L.T. PANELS | | | | | 1. Name of Technician POWER FAILURE/DG RUN FROM TO FROM TO FROM TO FROM TO |
| 8 AM | | | | | 1 MILK RECEPTION | | | | | Sign. of Technician |
| 9 AM | | | | | 2 MILK PROCESSING | | | | | |
| 10 AM | | | | | 3 LIQUID MILK | | | | | |
| 11 AM | | | | | 4 BUTTER & CHEE | | | | | B SHIFT |
| 12 AM | | | | | 5 EVAPORATOR | | | | | 1. Name of Technician POWER FAILURE/DG RUN FROM TO FROM TO FROM TO FROM TO |
| 1 PM | | | | | 6 SPRAY DRYER | | | | | Sign. of Technician |
| 2 PM | | | | | 7 BOILER | | | | | |
| 3 PM | | | | | 8 REFRIGERATION | | | | | C SHIFT |
| 4 PM | | | | | 9 ETP | | | | | 1. Name of Technician POWER FAILURE/DG RUN FROM TO FROM TO FROM TO FROM TO |
| 5 PM | | | | | 10 LIGHTING PANEL | | | | | Sign. of Technician |
| 6 PM | | | | | 11 WATER SUPPLY | | | | | |
| | | | | | 12 SUBMERSIBLE PUMP | | | | | |
| 6 AM | | | | | | | | | | |
| 7 PM | | | | | 13 MAIN L.T PANEL | | | | | 1. Name of Technician POWER FAILURE/DG RUN FROM TO FROM TO FROM TO FROM TO |
| 8 PM | | | | | B Trivector Meter Reading | | | | | Sign. of Technician |
| 9 PM | | | | | 1 KWH READING | | | | | |
| 10 PM | | | | | 2 KVAH READING | | | | | |
| 11 PM | | | | | 3 MDI READING | | | | | |
| | | | | | | | | | | |
| 12 PM | | | | | 4 DIESEL TANK READING | | A | B | C | CONSUMPTION |
| 1 AM | | | | | a INITIAL TANK-I | | | | | A. KWH CONSUMPTION TODAY |
| 2 AM | | | | | b FINAL TANK | | | | | C. POWER FACTOR |
| 3 AM | | | | | 5 FILLING TANK | | | | | D. KWH CONSUMPTION UPTO DATE |
| 4 AM | | | | | a INITIAL TANK-II | | | | | E. KVAH CONSUMPTION UPTO DATE |
| 5 AM | | | | | b FINAL TANK | | | | | F. DIESEL CONSUMPTION TODAY |
| 6 AM | | | | | 6 DG-I (KWH) | | | | | G. DIESEL CONSUMPTION UPTO DATE |
| | | | | | 7 DG- II (KWH) | | | | | |

EXECUTIVE TECHNICAL ELECTRICAL

Prepared By: **H O D** Date: 01.04.04
Signature: _____ Date: 01.04.04
Issue No. 01

Approved by CEO Date: 01.04.04
Signature: _____ Date: 01.04.04
Revision No. 0

INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD.
 DIESEL GENSET LOG SHEET

| DATE | START | | VOLTS | AMPS | KW | P.F. | RPM | DIESEL OIL PRESSURE PSI | WATER TEMP °C | ENGINE OIL PRESSURE PSI | STOP | | RUNNING HOURS | UNITS GENERATED | DIESEL CONSUMMED | REPAIRS & REMARKS | OPERATOR'S SIGN. |
|------|-------|-----|-------|------|----|------|-----|-------------------------|---------------|-------------------------|------|-----|---------------|-----------------|------------------|-------------------|------------------|
| | TIME | SMU | | | | | | | | | TIME | SMU | | | | | |
| | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | |

A :- DG-I LOG SHEET
 B :- DG-II LOG SHEET

H. O. D. (ENGG.)

Prepared By **H O D** Approved by CEO
 Signature _____ Date 01.04.04 Signature _____ Date 01.04.04
 Issue No. 01 Revision No. 0 Issue No. 0 Date 01.04.04

| TIME HOURS | STEAM PRESSURE (KGS/cm ²) | TEMPERATURE °C | | HUSK FEEDER R.P.M. | | DRAUGHTS MM WC | | DRUM WATER LEVEL | BLOW DOWN OPERATED AT (TIME) | FEED WATER | | TYPE OF WATER | WATER ANALYSIS | | | TEMPERATURE | | | SHIFT REPORT | REMARKS IF ANY | |
|------------|---------------------------------------|----------------|----------|--------------------|----------|----------------|-----------|------------------|------------------------------|------------|----------|---------------|----------------|----------|-----|-------------|---------|------------|--------------|----------------|--|
| | | BED NO.1 | BED NO.2 | BED NO.1 | BED NO.2 | FD FAN-01 | FD FAN-02 | | | PH | HARDNESS | | PH | HARDNESS | PPM | TDS | FLU GAS | FEED WATER | | | |
| 6 AM | | | | | | | | | | | | FEED TANK | | | | | | | | | |
| 7 AM | | | | | | | | | | | | SOFTNER | | | | | | | | | |
| 8 AM | | | | | | | | | | | | CONDENSATE | | | | | | | | | |
| 9 AM | | | | | | | | | | | | BOILER | | | | | | | | | |
| 10 AM | | | | | | | | | | | | | | | | | | | | | |
| 11 AM | | | | | | | | | | | | | | | | | | | | | |
| 12 AM | | | | | | | | | | | | | | | | | | | | | |
| 1 PM | | | | | | | | | | | | FEED TANK | | | | | | | | | |
| 2 PM | | | | | | | | | | | | SOFTNER | | | | | | | | | |
| 3 PM | | | | | | | | | | | | CONDENSATE | | | | | | | | | |
| 4 PM | | | | | | | | | | | | BOILER | | | | | | | | | |
| 5 PM | | | | | | | | | | | | | | | | | | | | | |
| 6 PM | | | | | | | | | | | | | | | | | | | | | |
| 7 PM | | | | | | | | | | | | FEED TANK | | | | | | | | | |
| 8 PM | | | | | | | | | | | | SOFTNER | | | | | | | | | |
| 9 PM | | | | | | | | | | | | CONDENSATE | | | | | | | | | |
| 10 PM | | | | | | | | | | | | BOILER | | | | | | | | | |
| 11 PM | | | | | | | | | | | | | | | | | | | | | |
| 12 PM | | | | | | | | | | | | | | | | | | | | | |
| 1 AM | | | | | | | | | | | | | | | | | | | | | |
| 2 AM | | | | | | | | | | | | | | | | | | | | | |
| 3 PM | | | | | | | | | | | | | | | | | | | | | |
| 4 AM | | | | | | | | | | | | | | | | | | | | | |
| 5 AM | | | | | | | | | | | | | | | | | | | | | |

DATE :.....

Approved by CEO
 Signature _____ Date 01.04.04
 Revision No. 0 Date 01.04.04

Prepared By HOD
 Signature _____ Date 01.04.04
 Issue No. 01 Date 01.04.04

| HOURS | EQUALISATION TANK | | | | AERATION TANK | | | | SLUDGE RECIRCULATION CLARIFIER - II | | SLUDGE DISCHARGE CLARIFIER - I | | SLUDGE DISCHARGE CLARIFIER - II | | PARTICULARS | CHEMICAL CONSUMPTION | | | | | | | | |
|--------------------------------|-------------------|-------|-------------|-------|---------------|-------|---------|-------|-------------------------------------|-------|--------------------------------|-------|---------------------------------|------|-------------|----------------------|------|-------|------|---------|-----------|--------|---------|--|
| | Aerator | | Sludge Pump | | PH | | Aerator | | Sludge Pump | | PH | | Start | Stop | | Start | Stop | Start | Stop | ALUM Kg | CR - I Kg | DAP Kg | UREA Kg | |
| | No. 1 | No. 2 | No. 1 | No. 2 | No. 1 | No. 2 | No. 1 | No. 2 | No. 1 | No. 2 | No. 1 | No. 2 | | | | | | | | | | | | |
| 0600 | | | | | | | | | | | | | | | | | | | | | | | | |
| 0700 | | | | | | | | | | | | | | | | | | | | | | | | |
| 0800 | | | | | | | | | | | | | | | | | | | | | | | | |
| 0900 | | | | | | | | | | | | | | | | | | | | | | | | |
| 1000 | | | | | | | | | | | | | | | | | | | | | | | | |
| 1100 | | | | | | | | | | | | | | | | | | | | | | | | |
| 1200 | | | | | | | | | | | | | | | | | | | | | | | | |
| 1300 | | | | | | | | | | | | | | | | | | | | | | | | |
| 1400 | | | | | | | | | | | | | | | | | | | | | | | | |
| 1500 | | | | | | | | | | | | | | | | | | | | | | | | |
| 1600 | | | | | | | | | | | | | | | | | | | | | | | | |
| 1700 | | | | | | | | | | | | | | | | | | | | | | | | |
| 1800 | | | | | | | | | | | | | | | | | | | | | | | | |
| 1900 | | | | | | | | | | | | | | | | | | | | | | | | |
| 2000 | | | | | | | | | | | | | | | | | | | | | | | | |
| 2100 | | | | | | | | | | | | | | | | | | | | | | | | |
| 2200 | | | | | | | | | | | | | | | | | | | | | | | | |
| 2300 | | | | | | | | | | | | | | | | | | | | | | | | |
| 2400 | | | | | | | | | | | | | | | | | | | | | | | | |
| 0100 | | | | | | | | | | | | | | | | | | | | | | | | |
| 0200 | | | | | | | | | | | | | | | | | | | | | | | | |
| 0300 | | | | | | | | | | | | | | | | | | | | | | | | |
| 0400 | | | | | | | | | | | | | | | | | | | | | | | | |
| 0500 | | | | | | | | | | | | | | | | | | | | | | | | |
| 0600 | | | | | | | | | | | | | | | | | | | | | | | | |
| Prepared By HOD | | | | | | | | | | | | | | | | | | | | | | | | |
| Signature _____ Date 01.04.04 | | | | | | | | | | | | | | | | | | | | | | | | |
| Issue No. 01 Date 01.04.04 | | | | | | | | | | | | | | | | | | | | | | | | |
| Approved by CEO | | | | | | | | | | | | | | | | | | | | | | | | |
| OPERATOR'S SIGNATURE A - B - C | | | | | | | | | | | | | | | | | | | | | | | | |
| EXECUTIVES SIGNATURE _____ | | | | | | | | | | | | | | | | | | | | | | | | |
| REMARKS : - | | | | | | | | | | | | | | | | | | | | | | | | |

INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD.
 PERFORMANCE HISTORY OF DAIRY EQUIPMENT

SECTION :-

EQUIPMENT :-
 PREVENTIVE MAINTENANCE SCHEDULE
 FREQUENCY :-

LUBRICATION SCHEDULE FREQUENCY :-

| S.NO. | ACTION TAKEN AGAINST | JOB DESCRIPTION | JOB CODE | GROUP CODE | DUE DATE | ATTENDED DATE | ATTENDED BY | SIG. OF FOREMAN /SEC. INCHARGE | REMARKS |
|-------|----------------------|-----------------|----------|------------|----------|---------------|-------------|--------------------------------|---------|
| | | | | | | | | | |

Prepared By **HOD**

Approved by CEO

Signature _____ Date 01.04.04
 Issue No. 01 Date 01.04.04

Signature _____ Date 01.04.04
 Revision No. 0 Date 01.08.2003

[QME-06]

INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. PAGE NO. 09
 TITLE:- DEPARTMENTAL PROCEDURES ENGINEERING DATE :01.04.04

INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD.
 PERFORMANCE HISTORY OF STEAM GENERATION EQUIPMENTS (BOILER)
 SECTION :

EQUIPMENT :
 PREVENTIVE MAINTENANCE FREQUENCY :
 LUBRICATION SCHEDULE FREQUENCY :

| S.NO. | ACTION TAKEN AGAINST | JOB DESCRIPTION | JOB CODE | GROUP CODE | DUE DATE | ATTENDED DATE | ATTENDED BY | SIG. OF FOREMAN /SEC. INCHARGE | REMARKS |
|-------|----------------------|-----------------|----------|------------|----------|---------------|-------------|--------------------------------|---------|
| | | | | | | | | | |

Prepared By **H O D**
 Signature _____ Date 01.04.04
 Issue No. 01 _____ Date 01.04.04
 Approved by CEO
 Signature _____ Date 01.04.04
 Revision No. 0 _____ Date 01.08.2003
[QME-08]

INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. PAGE NO. 10
 TITLE:- DEPARTMENTAL PROCEDURES ENGINEERING DATE :01.04.04

INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD.
 PERFORMANCE HISTORY OF REFRIGERATION PLANT EQUIPMENT

EQUIPMENT : SECTION :
 PREVENTIVE MAINTENANCE FREQUENCY : LUBRICATION SCHEDULE FREQUENCY :

| S.NO. | ACTION TAKEN AGAINST | JOB DESCRIPTION | JOB CODE | JOB CODE | GROUP CODE | DUE DATE | ATTENDED DATE | ATTENDED BY | SIG. OF FOREMAN /SEC. INCHARGE | REMARKS |
|-------|----------------------|-----------------|----------|----------|------------|----------|---------------|-------------|--------------------------------|---------|
| | | | | | | | | | | |

Prepared By **H O D** Approved by **CEO**
 Signature _____ Date 01.04.04 Signature _____ Date 01.04.04
 Issue No. 01 Date 01.04.04 Revision No. 0 Date 01.08.2003

| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. | | | | | | PAGE NO. 11 | |
|---|---|---|--------------------|-----------------------------------|---------------------|------------------|----|
| TITLE :- DEPARTMENTAL PROCEDURES ENGINEERING | | | | | | DATE :- 01.04.04 | |
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. PREVENTIVE MAINTENANCE SCHEDULE OF D.G. SET | | | | | | | |
| R.NO NO. | SERVICE ITEMS | SERVICE METER UNITS (RUNNING HRS.) SMU | UNITS GENERATED | ATTENDED BY | SECTION INCHARGE | DATE | |
| | | | | | | 01 | 31 |
| 01 | DAILY CHECKS :- & AFTER EVERY 50 HRS. i) Check that fuel tank is filled up ii) Drain sediments and water from fuel tank and water separator iii) Check the engine oil level from dipstick iv) Check the Engine coolant level v) Check air cleaner service Indicator vi) Check the loose or broken fittings guard's (MR6) and components (MR6) and components vii) Inspect for worn/broken and loose belts viii) Check the battery connections and maintain electroyte level ix) Check the condition of all gauges,repair or replace any broken gauge x) Check the exaust manifold or air piping leakage | 50 HRS. | | | | | |
| 02 | CHANGE THE FOLLOWING PARTS AT EVERY 250 HRS i) Change the lubrication oil fill fresh lubrication oil (RX super plus) 15w/40 of castrol make ii) Change the lubrication of filters iii) Change the fuel filters iv) Change/wash the fuel separator filter v) Wash the primary fuel filter vi) Check the vibration mounting vii) Clean the radiator exernally viii) Add the 2.500ltr. of intac liquid coolant in the radiator ix) Check all hoses of the engine | 250 HRS. | | | | | |
| 03 | Check and adjust the tappet clearance | 2000 HRS | | | | | |
| Prepared by H O D | | | | Approved by CEO | | | |
| Signature _____ Date 01.04.04 | | | | Signature _____ Date 01.04.04 | | | |
| Issue No. 01 Date 01.04.04 | | | | Revision No. 0 Date 01.04.04 | | | |

[QME-10]

| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. | | | | PAGE NO. 13 | | | |
|---|--|------------------------------|--------------------|-------------------------------|----------------------------|----------------|-------------------------------|
| TITLE:- DEPARTMENTAL PROCEDURES ENGINEERING | | | | DATE :01.04.04 | | | |
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. MAINTENANCE REPORT (ELECTRICAL) | | | | | | | |
| VISIT NO. _____ | | | | MILK CHILLING CENTRE : _____ | | | |
| DATE: _____ | | | | DATE OF VISIT : _ | | | |
| SR. NO. | JOB DESCRIPTION | | CHILLED WATER PUMP | MILK PUMP | MILK STORAGE TANK AGITATOR | GENERATING SET | DOMESTIC FITTINGS/ APPLIANCES |
| 1 | Voltage | Volts | | | | | |
| 2 | Current | Amps. | | | | | |
| 3 | Insulation Resistance | O.K. / WEEK | | | | | |
| 4 | Condition of Barings | O.K./ Defective | | | | | |
| 5 | Running temperature | Normal/ abnormal | | | | | |
| 6 | Running sound | Normal/ abnormal | | | | | |
| 7 | Capacity of fuses | Amps. | | | | | |
| 8 | Relay setting | Amps. | | | | | |
| 9 | Earthing | O.K. /Done | | | | | |
| 10 | Clean & tighten all terminals/ contracts | O.K. /Done | | | | | |
| 11 | General Conditions | Satisfactory/ Unsatisfactory | | | | | |
| 12 | Action taken | | | | | | |
| TECHNICIAN | | | ZONE INCHARGE | | H. O. D. (ENGG.) | | |
| Prepared By H O D | | | | Approved by CEO | | | |
| Signature _____ Date 01.04.04 | | | | Signature _____ Date 01.04.04 | | | |
| Issue No. 01 | | Date 01.04.04 | | Revision No. 0 | | Date 01.04.04 | |

[QME-12]

| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. | | | | PAGE NO. 14 | | | |
|---|-----------------|------|------|----------------|---|------------|---------|
| TITLE:- DEPARTMENTAL PROCEDURES ENGINEERING | | | | DATE :01.04.04 | | | |
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. MAINTENANCE SCHEDULE FOR CHECKING THE CALIBRATION OF INSTRUMENTS INSTRUMENT ----- FREQUENCY ----- RANGE ----- SERVICE ----- | | | | | | | |
| DATE | SIMULATED VALUE | | | VARIATION | CALIBRATED BY | CHECKED BY | REMARKS |
| | UNIT | UNIT | UNIT | | | | |
| | DISPLAYED VALUE | | | | | | |
| | | | | | | | |
| Prepared By H O D | | | | | Approved by CEO | | |
| Signature _____ Date 01.04.04 | | | | | Signature _____ Date 01.04.04 | | |
| Issue No. 01 Date 01.04.04 | | | | | Revision No. 0 Date 01.04.04 | | |

(QME-13)

INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD.
PREVENTIVE MAINTENANCE/CALIBRATION OF WEIGHING SCALES

LOCATION - _____ FREQUENCY - _____
 CAPACITY - _____
 MAKE - _____
 SR.NO. - _____

| DATE | STANDARD WEIGHT | | | | CALIBRATED BY | CHECKED BY | REMARKS |
|------|------------------|----|----|----|---------------|------------|---------|
| | Kg | Kg | Kg | Kg | | | |
| | DISPLAYED WEIGHT | | | | | | |
| | | | | | | | |

| | |
|-------------------------------|-------------------------------|
| Prepared By HOD | Approved by CEO |
| Signature _____ Date 01.04.04 | Signature _____ Date 01.04.04 |
| Issue No 01 Date 01.04.04 | Revision No 0 Date 01.04.04 |

**INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD.
BASIC EQUIPMENT DATA SHEET**

| S.NO | PARTICULARS | |
|------|--|--|
| 1 | NAME | |
| 2 | SUPPLIER | |
| 3 | PURCHASE ORDER NO | |
| 4 | DATES A) RECEIVED B) INSTALLED C) COMMISSIONED | |
| 6 | COST OF MACHINE | |
| 7 | EXPECTED LIFE | |
| 8 | MODEL & STYLE NO. | |
| 9 | CAPACITY | |
| 10 | IDENTIFICATION OF MANUFACTURER'S INSTRUCTION MANNUAL | |
| 11 | IDENTIFICATION OF MANUFACTURER'S DRAWING. | |
| 12 | A) LUBRICANT TO BE USED B) COOLENT TO BE USED | |
| 13 | BASIC MECHANICAL DETAILS e.g. A) BEARING NO. B) BELT NO. | |
| 14 | ELECTRICAL DETAILS : MOTOR HP MAKE LIMIT SWITCHES STARTER MOTOR BEARINGS | |
| 15 | UTILITIES | |
| 16 | LUBRICATION DETAILS | |

Prepared By **H O D**

Approved by CEO

Signature _____ Date 01.04.04

Signature _____ Date 01.04.04

Issue No. 01 Date 01.04.04

Revision No. 0 Date 01.04.04

{QME-15}

INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD.
ANNUAL MAINTENANCE SCHEDULE

01 of 05

| DATE | ACTION | EQUIPMENTS | PARTS DESCRIPTION | PART POSITION | PART CHANGE | M/C OPENED BY | M/C FITTED BY | SIGN.OF EXE. TECH. | SIGN.OF PRODUCTION INCHARGE | REMARKS |
|------|--------|-----------------|---|---------------|-------------|---------------|---------------|--------------------|-----------------------------|---------|
| | DRYER | ROTO PUMP | 1) Bearing of motor 2) Bearing of Roto Pump 3) Varnish of Motor 4) Checking of Stator 5) Checking of Belts 6) Cleaning of S.S.Parts | | | | | | | |
| | | DEHUMIDIFIER | 1) Checking & Cleaning of Fins. 2) Checking of valves. 3) Cleanining of coils. | | | | | | | |
| | | NECKCOOLING FAN | 1) Bearing of motor 3) Varnish of Motor 3) Bearing of Fan 4) Belts position 5) Fan shaft position 6) Impeller 7) Distance piece canvas cloth position | | | | | | | |
| | | AIR SUPPLY FAN | 1) Bearing of Motor 3) Varnish of Motor 3) Beraing of Fan 4) Belts Position 5) Fan Shaft Position 6) Impeller Position & Cleaning 7) Distance piece canvas cloth position | | | | | | | |
| | | P.C.FAN | 1) Bearing of Motor 3) Varnish of Motor 3) Bearing of Fan 4) Shaft position 5) Impeller position 6) Belts Checking 7) Distance piece canvas cloth position 8) Supports checking of pipe ducts. | | | | | | | |

Prepared By H O D

Approved by CEO

Signature _____ Date 01.04.04

Signature _____ Date 01.04.04

Issue No. 01 Date 01.04.04

Revision No. 0 Date 01.04.04

(QME-16)

| DATE | SECTION | EQUIPMENTS | PARTS DESCRIPTION | PART POSITION | PART CHANGE | M/C OPENED BY | M/C FITTED BY | SIGN.OF EXE. TECH. | SIGN.OF PRODUCTION INCHARGE | REMARKS |
|------|---------|--|--|---------------|-------------|---------------|---------------|--------------------|-----------------------------|---------|
| | | EXHAST FAN | 1) Bearing of motor. 3) Varnish of Motor 3) Bearing of Fan 4) Shaft position 5) Impeller checking & Cleaning 6) Belts checking 7) Distance piece canvas cloth Position 8) Supports of Ducts. | | | | | | | |
| | | ATOMIZER | 1) Shaft Alignment. 2) Checking of oil pipe lines. 3) Checking of Ball Bearing 4) Checking of G.M. Bush 5) Checking of Shaft thread 6) Checking of Distribution Plate - tightening Nut. 7) Checking of G.M. Bush Tightening Nut 8) Varnish of Motor 9) Ball bearing of Motors. 10)Checking of Belts | | | | | | | |
| | | ATOMIZER CONE.FIRE DOORS,MAIN GATE CHAMBER,CYCLONE MANHOLE GASKETS.AND ROTARY VALVES | 1) Silicon gasket strip 1) Silicon gasket cord 3) Ball bearing of R.V. 4) Bush of R.V. 5) Position of Rotor 6) Belts Position 7) Motor Bearing 3) Varnish of Motor | | | | | | | |
| | | HAMMERS OF CHAMBER, AIRLINE CLEANING & AIR FILTER CHECKING | 1) Aluminium piston 2) O Rings 3) Solenoid Valves 4) Air filter's O Ring 5) Airfilter Glass 6) Airfilter Gauge 7) Air line Valve leakage | | | | | | | |

Prepared By H O D

Approved by CEO

Signature _____ Date 01.04.04

Signature _____ Date 01.04.04

Issue No. 01 Date 01.04.04

Revision No. 0 Date 01.04.04

| DATE | SECTION | EQUIPMENTS | PARTS DESCRIPTION | PART POSITION | PART CHANGE | M/C OPENED BY | M/C FITTED BY | SIGN.OF EXE. TECH. | SIGN.OF PRODUCTION INCHARGE | REMARKS |
|------|------------|--|--|---------------|-------------|---------------|---------------|--------------------|-----------------------------|---------|
| | | SILOS - 03 NOS. | 1) Silo manhole gasket 2) Sampling valve 3) Main S.S. Valve 65 mm 4) Main pipe line valves 5) 2 Nos. milk feed pump. a) Motor Bearing b) Impeller c) Carbon seal d) Varnish of Motor e) Lip seal f) Stationary Seal g) O Ring for housing & others. | | | | | | | |
| | | PRESSURE REGULATING VALVES STATION IN EVAPORATOR & DRYER | 1) Pneumatic valve position 2) Pneumatic valve gauge 3) C.S.Valves position 4) Flange end gaskets position | | | | | | | |
| | | WATERLINE VALVES | 1) Valves position 2) Flanged gasket position | | | | | | | |
| | | MILK VALVE S S TYPE | 1) Valves Position 2) O Rings position | | | | | | | |
| | EVAPORATOR | CALANDERIA NO.1 FEED PUMP MODEL LKH-10 ONE PUMP | 1) Bearing of motor 2) Carbon Seal 3) Lip Seal 4) Impeller 5) Stationary Seal 6) O Rings & other Housekeeping. 7) Motor Varnish | | | | | | | |
| | | CALANDERIA NO.2 FEED PUMP MODEL LKH-10 TWO PUMP | 1) Bearing of motor 2) Carbon seal 3) Lip seal 4) Impeller 5) Stationary seal 6) O Rings & other Housekeeping. 7) Motor Varnish. | | | | | | | |

Prepared By H O D

Approved by CEO

Signature _____ Date 01.04.04

Signature _____ Date 01.04.04

Issue No. 01 Date 01.04.04

Revision No. 0 Date 01.04.04

| DATE | SECTION | EQUIPMENTS | PARTS DESCRIPTION | PART POSITION | PART CHANGE | M/C OPENED BY | M/C FITTED BY | SIGN.OF EXE. TECH. | SIGN.OF PRODUCTION INCHARGE | REMARKS |
|------|---------|---|--|---------------|-------------|---------------|---------------|--------------------|-----------------------------|---------|
| | | CALANDERIA NO.3 FEED PUMP MODEL LKH-10 FOUR PUMPS | 1) Bearing of motor 2) Carbon seal 3) Lip seal 4) Impeller 5) Stationary seal 6) O Rings & other Housekeeping. 7) Motor Varnish. | | | | | | | |
| | | CALANDERIA NO.4 FEED PUMP MODEL LKH-10 TWO PUMPS | 1) Bearing of motor 2) Carbon seal 3) Lip seal 4) Impeller 5) Stationary seal 6) O Rings & other Housekeeping. 7) Motor Varnish. | | | | | | | |
| | | CALANDERIA FINISHER & DST UNIT | 1) 1 Bolts 2) Top cover Gasket 3) Man hole cover gasket 4) Orifices gaskets 5) Non return valve Balls | | | | | | | |
| | | EVAPORATOR CONDENSER CLEANING,SPRAY POND. PUMPS | 1) Bearing of Motor 7) Motor Varnish. 3) Gland packing 4) G.M. Bush 5) Impeller 6) O Rings packing 7) Non return valves. | | | | | | | |
| | | MILK FEED PUMP MODEL ALC-2 TWO NO. PUMPS | 1) Bearing of Motor 2) Motor Varnish. 3) Carbon Seal 4) Stationary seal 5) Lip seal 6) Impeller 7) O Rings & other Housekeeping. | | | | | | | |
| | | SELF PRIMING PUMP FOR CONDENSATE LIFTING | 1) Bearing of Motor 2) Motor Varnish 3) Gland packing 4) G.M. Bush 5) Impeller | | | | | | | |

Prepared By H O D

Approved by CEO

Signature _____ Date 01.04.04

Signature _____ Date 01.04.04

Issue No. 01 Date 01.04.04

Revision No. 0 Date 01.04.04

| DATE | SECTION | EQUIPMENTS | PARTS DESCRIPTION | PART POSITION | PART CHANGE | M/C OPENED BY | M/C FITTED BY | SIGN.OF EXE. TECH. | SIGN.OF PRODUCTION INCHARGE | REMARKS |
|------|------------------|--|---|---------------|-------------|---------------|---------------|--------------------|-----------------------------|---------|
| | | FINISHER FEED PUMP MODEL LKH-10 | 1) Bearing of Motor 2) Motor Varnish. 3) Carbon Seal 4) Stationary seal 5) Lip seal 6) Impeller 7) O Rings & other Housekeeping. | | | | | | | |
| | | DSI UNIT FEED PUMP TWO NOS | 1) Bearing of Motor 2) Motor Varnish. 3) Carbon Seal 4) Stationary seal 5) Lip seal 6) Impeller 7) O Rings & other Housekeeping. | | | | | | | |
| | | CONDENSATE WATER PUMP MODEL AKAY TWO NOS | 1) Bearing of Motors 2) Motor Varnish 3) Carbon Seal 4) Lip Seal 5) Stationary Seal 6) O Rings Housekeeping & Others. 7) Impeller | | | | | | | |
| | | VACUUM PUMP TWO NOS | 1) Bearing of Motors 2) Motor Varnish 3) Carbon Seal 4) Lip Seal 5) Stationary Seal 6) O Rings Housekeeping & Others. 7) Impeller | | | | | | | |
| | PROCE- -SSING | CREAM SEPARATOR 3 NOS | 1) Bearing of Motor 2) Motor Varnish 3) Gear Assembly 4) G.M. Bush 5) Impeller 6) Bearing of Separator | | | | | | | |
| | GHEE SEC. | BUTTER CHURN 2 NOS | 1) Bearing of Motor 2) Motor Varnish. 3) Neoprene Bush | | | | | | | |

| | |
|---|---|
| Prepared By H O D | Approved by CEO |
| Signature _____ Date 01.04.04 | Signature _____ Date 01.04.04 |
| Issue No. 01 Date 01.04.04 | Revision No. 0 Date 01.04.04 |

INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD.
CORRECTIVE MAINTENANCE RECORD

| SL. NO. | DATE/TIME | DETAILS OF BREAKDOWN | INFORMED BY | ATTENDED BY | | REASONS OF BREAKDOWN | TIME TAKEN RECTIFY B/D | SIGNATURES | | |
|---|-----------|----------------------|-------------|-------------|--------|---|------------------------|------------|--------|-------|
| | | | | DATE/TIME | FITTER | | | S/I | FITTER | FM/EX |
| | | | | | | | | | | |
| Prepared By H O D | | | | | | Approved by CEO | | | | |
| Signature _____ Date 01.04.04 | | | | | | Signature _____ Date 01.04.04 | | | | |
| Issue No. 01 Date 01.04.04 | | | | | | Revision No. 0 Date 01.04.04 | | | | |

(QME-17)

| | | | | | |
|---|-----------------------|--------------------------------|---|------------------------------------|---------|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. | | | PAGE NO. 23 | | |
| TITLE:- DEPARTMENTAL PROCEDURES ENGINEERING | | | DATE :01.04.04 | | |
| DAILY REPORT ENGINEERING | | | | DATE : _____ | |
| BREAK DOWN & PRODUCTION DOWN TIME | | | IMPLEMENTATION OF LUBRICATION P. M. PROGRAMME | MACHINES OUT OF ORDER UNDER REPAIR | |
| SECTION | NUMBER OF BREAK DOWNS | PRODUCTION DOWN TIME HRS. MIN. | | | |
| MECHANICAL | | | YES / NO | | |
| ELECTRICAL | | | YES / NO | | |
| REFRIGERATION | | | YES / NO | | |
| BOILER | | | YES / NO | | |
| WATER SUPPLY | | | YES / NO | | |
| E.T.P | | | YES / NO | | |
| WEIGHING MACHINES | | | YES / NO | | |
| MILK CHILLING CENTRES | | | YES / NO | | |
| MISC. | | | YES / NO | | |
| CONSUMPTION OF UTILITIES | | | 1. MILK RECEIPT KG | | |
| | | | 2. MILK HANDLING KG | | |
| | | | 3. SMP MFD. KG | | |
| UTILITY | CONSUMPTION | NORMS PER 1000 L MILK HANDLING | ACTUAL PER 1000 L MILK HANDLING | VARIATION PER 1000 KG | REMARKS |
| WATER | | | | | |
| ELECTRICITY (Unit) | | | | | |
| FUEL | | | | | |
| DIESEL (Uint Per Lt) | | | | | |
| REFRIGERATION (Running Hrs. of Cmpressors) | | | | | |
| E.T.P | | | | | |
| FERRIC ALUM | | | | | |
| POLY ELECTROLITE | | | | | |
| PERFORMANCE OF BOILER AS PER ACT REGULATIONS. | | | YES/NO | | |
| PERFORMANCE OF E.T.P. AS PER ACT REGULATIONS. | | | YES/NO | | |
| Water Meter Reading | Submersible | E.T.P. | FOREMAN INCHARGE. (ENGG.) | | |
| Opening | | | | | |
| Closing | | | | | |
| Consumption | | | | | |
| | | | | | |
| Prepared By H O D | | | Approved by CEO | | |
| Signature _____ Date 01.04.04 | | | Signature _____ Date 01.04.04 | | |
| Issue No. 01 Date 01.04.04 | | | Revision No. 0 Date 01.04.04 | | |

[QME-18]

| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. | | | | PAGE NO. | 24 |
|--|-------------------|---------------------|---|---------------------------------------|-----------|
| TITLE:- DEPARTMENTAL PROCEDURES ENGINEERING | | | | DATE | :01.04.04 |
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. CALIBRATION/RE-CHECK OF STANDARDS MEASURING INSTRUMENTS | | | | | |
| SL. NO. | NAME OF EQUIPMENT | DATE OF CALIBRATION | CALIBRATION DUE ON | SIGNATURE OF INST. ENGG/ EXEC.(ENGG.) | REMARKS |
| | | | | | |
| Prepared By H O D | | | Approved by CEO | | |
| Signature _____ Date 01.04.04 | | | Signature _____ Date 01.04.04 | | |
| Iss ue No. 01 Date 01.04.04 | | | Revision No. 0 Date 01.04.04 | | |

{QMQ-19}

| | |
|---|----------------|
| INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD. | PAGE NO. 25 |
| TITLE:- DEPARTMENTAL PROCEDURES ENGINEERING | DATE :01.04.04 |

**INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD.
CIVIL WORK RECORD**

| DATE | SR.NO. | CIVIL MAINT. | COMPLETED DATE | CHECKED BY | REMARKS |
|------|--------|--------------|----------------|------------|---------|
| | | | | | |

| | |
|--|---|
| Prepared By H O D Signature _____ Date 01.04.04 Issue No. 01 Date 01.04.04 | Approved by CEO Signature _____ Date 01.04.04 Revision No. 0 Date 01.04.04 |
|--|---|

[QME-20]

INNOVATIVE BUSINESS IMPROVEMENTS (PVT.) LTD.

LIST OF QUALITY RECORDS

DEPARTMENT ENGINEERING

QR-ENG- 05 OF 05

| S.NO. | PARTICULARS | FORMAT/ FILE NO. | ITEM CODE | LOCATION | RETENTION PERIOD |
|-------|--|---------------------|--------------------|-----------------------|---------------------|
| 1 | LOG BOOK FOR REFRIGERATION PLANT | QME-01 | IBI/ENGG/R/DLS/01 | IBI/ENGG/REF/FR-01 | 1 YEAR |
| 2 | LOG BOOK FOR REFRIGERATION PLANT (ICE CREAM) | QME-01A | IBI/ENGG/R/DLS/01A | IBI/ENGG/REF/FR-01 | 1 YEAR |
| 3 | DAILY LOG SHEET FOR ELECTRICAL | QME-02 | IBI/ENGG/R/DLS/02 | IBI/ENGG/ELECT/FR-01 | 1 YEAR |
| 4 | GENSET LOG SHEET NO.1 | QME-03A | IBI/ENGG/R/DLS/03A | IBI/ENGG/ELECT/FR-01 | 1 YEAR |
| 5 | GENSET LOG SHEET NO.11 | QME-03B | IBI/ENGG/R/DLS/03B | IBI/ENGG/ELECT/FR-01 | 1 YEAR |
| 6 | DAILY LOGBOOK STEET BOILER | QME-04 | IBI/ENGG/R/DLS/04 | IBI/ENGG/BOILER/FR-01 | 1 YEAR |
| 7 | DAILY LOG SHEET EFFLUENT TREATMENT PLANT | QME-05 | IBI/ENGG/R/DLS/05 | IBI/ENGG/ETP/FR-01 | 1 YEAR |
| 8 | PERFORMANCE HISTORY OF DAIRY EQUIPMENT | QME-06 | IBI/ENGG/R/PHD/06 | IBI/ENGG/A/S/FR-03 | 1 YEAR |
| 9 | PERFORMANCE HISTORY OF ELECTRICAL EQUIPMENT | QME-07 | IBI/ENGG/R/PHE/07 | IBI/ENGG/ELECT/FR-01 | 1 YEAR |
| 10 | PERFORMANCE HISTORY OF STEAM GENERATION EQUIPMENT (BOILER) | QME-08 | IBI/ENGG/R/PHB/08 | IBI/ENGG/BOILER/FR-01 | 1 YEAR |
| 11 | PERFORMANCE HISTORY OF REFRIGERATION PLANT | QME-09 | IBI/ENGG/R/PMR/09 | IBI/ENGG/REF/FR-01 | 1 YEAR |
| 12 | PREVENTIVE MAINT. SCHEDULE FOR DG SETS | QME-10 | IBI/ENGG/R/PMDG/10 | IBI/ENGG/ELECT/FR-01 | 1 YEAR |
| 13 | MAINTENANCE REPORT MCC (GENERAL) | QME-11 | IBI/ENGG/F/MR/11 | IBI/ENGG/FC-01/C-01 | 1 YEAR |
| 14 | MAINTENANCE REPORT ELECTRICAL MCC (GENERAL) | QME-12 | IBI/ENGG/F/MR/12 | IBI/ENGG/FC-01/C-01 | 1 YEAR |
| 15 | PREVENTIVE MAINTENANCE AND CALIBRATION OF INSTRUMENTS | QME-13 | IBI/ENGG/R/IC/13 | IBI/ENGG/FC-01/C-01 | 1 YEAR |
| 16 | PREVENTIVE MAINTENANCE AND CALIBRATION SCHEDULES OF WEIGHING SCALES | QME-14 | IBI/ENGG/R/MCWS/14 | IBI/ENGG/FC-01/C-01 | 1 YEAR |
| 17 | BASIC EQUIPMENT DATA SHEET | QME-15 | IBI/ENGG/F/BEDS/15 | IBI/ENGG/FC-01/C-02 | 1 YEAR |
| 18 | ANNUAL MAINTANACE SCHDULE | QME-16 | IBI/ENGG/R/AM/16 | IBI/ENGG/FC-01/C-03 | 1 YEAR |
| 19 | CORRECTIVE MAINTANANCE RECORDS | QME-17 | IBI/ENGG/R/CMR/17 | IBI/ENGG/A/S/FR-03 | 1 YEAR |
| 20 | DAILY REPORT ENGINEERING | QME-18 | IBI/ENGG/R/DR/18 | IBI/ENGG/FC-01/C-03 | 1 YEAR |
| 21 | TESTING CERTIFICATES OF STANDARD INSTRUMENTS | QME-19 | IBI/ENGG/F/TRS/19 | IBI/ENGG/FC-01/C-03 | 1 YEAR |
| 22 | CIVIL WORK RECORD | QME-20 | IBI/ENGG/R/CWR/20 | IBI/ENGG/FC-01/C-03 | 1 YEAR |

LIST OF QUALITY RECORDS

DEPARTMENT: ENGINEERING

ADMINISTRATIVE FILES

QR - ENG - 04 OF 05

| SRNO | PARTICULARS | FORMAT/ FILE NO. | ITEM CODE | LOCATION | SUB.LOC | RETENTION PERIOD |
|------|---------------------------------------|---------------------|--------------------|---------------------|---------|---------------------|
| 01 | SANCTIONS | F - 1 | IBI/ENGG/F/S-01 | IBI/ENGG/FC-01/C-02 | | 1 YEAR |
| 02 | ISO 9002 QUALITY MANUAL | F - 2 | IBI/ENGG/F/ISO-02 | IBI/ENGG/FC-01/C-02 | | 1 YEAR |
| 03 | CORRESPONDENCE WITH PNL & HRD | F - 3 | IBI/ENGG/F/PD-03 | IBI/ENGG/FC-01/C-02 | | 1 YEAR |
| 04 | MINUTES OF MEETING | F - 4 | IBI/ENGG/F/MM-04 | IBI/ENGG/FC-01/C-02 | | 1 YEAR |
| 05 | CORRESPONDENCE WITH PRESIDENT | F - 5 | IBI/ENGG/F/P-05 | IBI/ENGG/FC-01/C-02 | | 1 YEAR |
| 06 | CORRESPONDENCE WITH ESTATE & SECURITY | F - 6 | IBI/ENGG/F/E&S-06 | IBI/ENGG/FC-01/C-02 | | 1 YEAR |
| 07 | CORRESPONDENCE WITH FINANCE DEPTT. | F - 7 | IBI/ENGG/F/A-07 | IBI/ENGG/FC-01/C-02 | | 1 YEAR |
| 08 | CORRESPONDENCE WITH GM(W) | F - 8 | IBI/ENGG/F/GM-08 | IBI/ENGG/FC-01/C-02 | | 1 YEAR |
| 09 | ENGINEERING DEPARTMENT FILE | F - 9 | IBI/ENGG/F/ED-09 | IBI/ENGG/FC-01/C-02 | | 1 YEAR |
| 10 | BASIC EQUIPMENT DATA SHEET | F - 10 | IBI/ENGG/F/BDES-10 | IBI/ENGG/FC-01/C-02 | | 1 YEAR |
| 11 | CORRESPONDANCE WITH QA | F - 11 | IBI/ENGG/F/QA-11 | IBI/ENGG/FC-01/C-02 | | 1 YEAR |
| 12 | DUTY ROSTER | F - 12 | IBI/ENGG/F/DR-12 | IBI/ENGG/FC-01/C-02 | | 1 YEAR |
| 13 | NCR | F - 13 | IBI/ENGG/F/NCR-13 | IBI/ENGG/FC-01/C-02 | | 1 YEAR |
| 14 | CORRESPONDANCE WITH PRODUCTION | F - 14 | IBI/ENGG/F/P-14 | IBI/ENGG/FC-01/C-02 | | 1 YEAR |
| 15 | CORRESPONDANCE WITH STORE | F - 15 | IBI/ENGG/F/S-15 | IBI/ENGG/FC-01/C-02 | | 1 YEAR |
| 16 | EXTRA DUTY | F - 16 | IBI/ENGG/F/ED-16 | IBI/ENGG/FC-01/C-02 | | 1 YEAR |
| 17 | CORRESPONDANCE WITH PURCHASE | F - 17 | IBI/ENGG/F/P-17 | IBI/ENGG/FC-01/C-02 | | 1 YEAR |
| 18 | CORRESPONDANCE WITH H.O | F - 18 | IBI/ENGG/F/HO-18 | IBI/ENGG/FC-01/C-02 | | 1 YEAR |
| 19 | CORRESPONDANCE WITH TRANSPORT | F - 19 | IBI/ENGG/F/TPT-19 | IBI/ENGG/FC-01/C-02 | | 1 YEAR |